

Code No.
----------



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF POINT AND NON-POINT SOURCE MANAGEMENT

## SEWAGE FACILITIES PLANNING MODULE

### Component 3. Sewage Collection and Treatment Facilities

*(Return completed module package to appropriate municipality)*

DEP USE ONLY				
DEP CODE #	CLIENT ID #	SITE ID #	APS ID #	AUTH ID #
02001-24-002				

This planning module component is used to fulfill the planning requirements of Act 537 for the following types of projects: (1) a subdivision to be served by sewage collection, conveyance or treatment facilities, (2) a tap-in to an existing collection system with flows on a lot of 2 EDU's or more, or (3) the construction of, or modification to, wastewater collection, conveyance or treatment facilities that will require DEP to issue or modify a Clean Streams Law permit. Planning for any project that will require DEP to issue or modify a permit cannot be processed by a delegated agency. Delegated agencies must send their projects to DEP for final planning approval.

This component, along with any other documents specified in the cover letter, must be completed and submitted to the municipality with jurisdiction over the project site for review and approval. All required documentation must be attached for the Sewage Facilities Planning Module to be complete. Refer to the instructions for help in completing this component.

**REVIEW FEES:** Amendments to the Sewage Facilities Act established fees to be paid by the developer for review of planning modules for land development. These fees may vary depending on the approving agency for the project (DEP or delegated local agency). Please see section R and the instructions for more information on these fees.

**NOTE:** All projects must complete Sections A through I, and Sections O through R. Complete Sections J, K, L, M and/or N if applicable or marked .

#### A. PROJECT INFORMATION (See Section A of instructions)

1. Project Name Sankofa Square Development

2. Brief Project Description Construction of a proposed 4-story commercial mixed-used building and associated parking lot.

#### B. CLIENT (MUNICIPALITY) INFORMATION (See Section B of instructions)

Municipality Name	County	City	Boro	Twp
City of Pittsburgh	Allegheny	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Municipality Contact Individual - Last Name	First Name	MI	Suffix	Title
Prendergast	Kyla			

Additional Individual Last Name	First Name	MI	Suffix	Title
---------------------------------	------------	----	--------	-------

Municipality Mailing Address Line 1	Mailing Address Line 2
200 Ross Street	3 <sup>rd</sup> Floor

Address Last Line -- City	State	ZIP+4
Pittsburgh	PA	15219

Area Code + Phone + Ext.	FAX (optional)	Email (optional)
		Kyla.Prendergast@PittsburghPA.Gov

**C. SITE INFORMATION** (See Section C of instructions)

**Site (Land Development or Project) Name**

Sankofa Square Development

Site Location Line 1

2100 Centre Avenue

Site Location Line 2

Site Location Last Line -- City

Pittsburgh

State

PA

ZIP+4

15219

Latitude

Longitude

Detailed Written Directions to Site From downtown Pittsburgh, head NW toward Liberty Avenue, turn right onto Liberty Avenue, turn right onto 6<sup>th</sup> Avenue, turn left onto Centre Avenue.

Description of Site 0.374 acre vacant parcel which is covered with ground vegetation. All public sewers and utilities are available to this site.

**Site Contact (Developer/Owner)**

Last Name

William

First Name

Irvin

MI

Suffix

Phone

412-434-6571

Ext.

Site Contact Title

Developer

FAX

Site Contact Firm (if none, leave blank)

Eholdings, Inc

Email

irvin.williams@sankofagr.com

Mailing Address Line 1

1801 Centre Avenue

Mailing Address Line 2

Suite 313

Mailing Address Last Line -- City

Pittsburgh

State

PA

ZIP+4

15219

**D. PROJECT CONSULTANT INFORMATION** (See Section D of instructions)

Last Name

Barton

First Name

Nile

MI

J

Suffix

Title

Professional Land Surveyor

Consulting Firm Name

NJBarton, LLC

Mailing Address Line 1

2000 Boles Court

Mailing Address Line 2

Address Last Line -- City

Bethel Park

State

PA

ZIP+4

15102

Country

USA

Email

njbartonllc@gmail.com

Area Code + Phone

412-855-3048

Ext.

Area Code + FAX

**E. AVAILABILITY OF DRINKING WATER SUPPLY**

The project will be provided with drinking water from the following source: (Check appropriate box)

- Individual wells or cisterns.
- A proposed public water supply.
- An existing public water supply.

If existing public water supply is to be used, provide the name of the water company and attach documentation from the water company stating that it will serve the project.

Name of water company: Pittsburgh Water and Sewer Authority

**F. PROJECT NARRATIVE** (See Section F of instructions)

- A narrative has been prepared as described in Section F of the instructions and is attached.

The applicant may choose to include additional information beyond that required by Section F of the instructions.

**G. PROPOSED WASTEWATER DISPOSAL FACILITIES** (See Section G of instructions)

Check all boxes that apply, and provide information on collection, conveyance and treatment facilities and EDU's served. This information will be used to determine consistency with Chapter 93 (relating to wastewater treatment requirements).

**1. COLLECTION SYSTEM**

a. Check appropriate box concerning collection system

- New collection system     Pump Station     Force Main  
 Grinder pump(s)     Extension to existing collection system     Expansion of existing facility

Clean Streams Law Permit Number \_\_\_\_\_

b. Answer questions below on collection system

Number of EDU's and proposed connections to be served by collection system. EDU's 33

Connections 1

Name of:

existing collection or conveyance system Hemans Street 15" VCP

owner Pittsburgh Water and Sewer Authority

existing interceptor Monongahela River

owner Allegheny County Sanitary Authority (ALCOSAN)

**2. WASTEWATER TREATMENT FACILITY**

Check all boxes that apply, and provide information on collection, conveyance and treatment facilities and EDU's served. This information will be used to determine consistency with Chapter(s) 91 (relating to general provisions), 92 (relating to national Pollution Discharge Elimination System permitting, monitoring and compliance) and 93 (relating to water quality standards).

a. Check appropriate box and provide requested information concerning the treatment facility

- New facility     Existing facility     Upgrade of existing facility     Expansion of existing facility

Name of existing facility Allegheny County Sanitary Authority (ALCOSAN)

NPDES Permit Number for existing facility 25984

Clean Streams Law Permit Number \_\_\_\_\_

Location of discharge point for a new facility. Latitude \_\_\_\_\_ Longitude \_\_\_\_\_

b. The following certification statement must be completed and signed by the wastewater treatment facility permittee or their representative.

As an authorized representative of the permittee, I confirm that the ALCOSAN  
(Name from above) sewage treatment facilities can accept sewage flows from this project without adversely affecting the facility's ability to achieve all applicable technology and water quality based effluent limits (see Section I) and conditions contained in the NPDES permit identified above.

Name of Permittee Agency, Authority, Municipality ALCOSAN

Name of Responsible Agent Joe Fedor

Agent Signature Joe Fedor Date 1-12-24

(Also see Section I. 4.)

**G. PROPOSED WASTEWATER DISPOSAL FACILITIES** (Continued)

**3. PLOT PLAN**

The following information is to be submitted on a plot plan of the proposed subdivision.

- a. Existing and proposed buildings.
- b. Lot lines and lot sizes.
- c. Adjacent lots.
- d. Remainder of tract.
- e. Existing and proposed sewerage facilities. Plot location of discharge point, land application field, spray field, COLDS, or LVCOLDS if a new facility is proposed.
- f. Show tap-in or extension to the point of connection to existing collection system (if applicable).
- g. Existing and proposed water supplies and surface water (wells, springs, ponds, streams, etc.)
- h. Existing and proposed rights-of-way.
- i. Existing and proposed buildings, streets, roadways, access roads, etc.
- j. Any designated recreational or open space area.
- k. Wetlands - from National Wetland Inventory Mapping and USGS Hydric Soils Mapping.
- l. Flood plains or Flood prone areas, floodways, (Federal Flood Insurance Mapping)
- m. Prime Agricultural Land.
- n. Any other facilities (pipelines, power lines, etc.)
- o. Orientation to north.
- p. Locations of all site testing activities (soil profile test pits, slope measurements, permeability test sites, background sampling, etc. (if applicable).
- q. Soils types and boundaries when a land based system is proposed.
- r. Topographic lines with elevations when a land based system is proposed

**4. WETLAND PROTECTION**

YES NO

- a.   Are there wetlands in the project area? If yes, ensure these areas appear on the plot plan as shown in the mapping or through on-site delineation.
- b.   Are there any construction activities (encroachments, or obstructions) proposed in, along, or through the wetlands? If yes, Identify any proposed encroachments on wetlands and identify whether a General Permit or a full encroachment permit will be required. If a full permit is required, address time and cost impacts on the project. Note that wetland encroachments should be avoided where feasible. Also note that a feasible alternative **MUST BE SELECTED** to an identified encroachment on an exceptional value wetland as defined in Chapter 105. Identify any project impacts on streams classified as HQ or EV and address impacts of the permitting requirements of said encroachments on the project.

**5. PRIME AGRICULTURAL LAND PROTECTION**

YES NO

- Will the project involve the disturbance of prime agricultural lands?  
If yes, coordinate with local officials to resolve any conflicts with the local prime agricultural land protection program. The project must be consistent with such municipal programs before the sewage facilities planning module package may be submitted to DEP.  
If no, prime agricultural land protection is not a factor to this project.
- Have prime agricultural land protection issues been settled?

**6. HISTORIC PRESERVATION ACT**

YES NO

- Sufficient documentation is attached to confirm that this project is consistent with DEP Technical Guidance 012-0700-001 *Implementation of the PA State History Code* (available online at the DEP website at [www.dep.state.pa.us](http://www.dep.state.pa.us), select "subject" then select "technical guidance"). As a minimum this includes copies of the completed Cultural Resources Notice

(CRN), a return receipt for its submission to the PHMC and the PHMC review letter.

**7. PROTECTION OF RARE, ENDANGERED OR THREATENED SPECIES**

Check one:

- The "Pennsylvania Natural Diversity Inventory (PNDI) Project Environmental Review Receipt" resulting from my search of the PNDI database and all supporting documentation from jurisdictional agencies (when necessary) is/are attached.
- A completed "Pennsylvania Natural Diversity Inventory (PNDI) Project Planning & Environmental Review Form," (PNDI Form) available at [www.naturalheritage.state.pa.us](http://www.naturalheritage.state.pa.us), and all required supporting documentation is attached. I request DEP staff to complete the required PNDI search for my project. I realize that my planning module will be considered incomplete upon submission to the Department and that the DEP review will not begin, and that processing of my planning module will be delayed, until a "PNDI Project Environmental Review Receipt" and all supporting documentation from jurisdictional agencies (when necessary) is/are received by DEP.

Applicant or Consultant Initials \_\_\_\_\_.

**H. ALTERNATIVE SEWAGE FACILITIES ANALYSIS** (See Section H of instructions)

- An alternative sewage facilities analysis has been prepared as described in Section H of the attached instructions and is attached to this component.  
The applicant may choose to include additional information beyond that required by Section H of the attached instructions.

**I. COMPLIANCE WITH WATER QUALITY STANDARDS AND EFFLUENT LIMITATIONS** (See Section I of instructions) (Check and complete all that apply.)

**1. Waters designated for Special Protection**

- The proposed project will result in a new or increased discharge into special protection waters as identified in Title 25, Pennsylvania Code, Chapter 93. The Social or Economic Justification (SEJ) required by Section 93.4c. is attached.

**2. Pennsylvania Waters Designated As Impaired**

- The proposed project will result in a new or increased discharge of a pollutant into waters that DEP has identified as being impaired by that pollutant. A pre-planning meeting was held with the appropriate DEP regional office staff to discuss water quality based discharge limitations.

**3. Interstate and International Waters**

- The proposed project will result in a new or increased discharge into interstate or international waters. A pre-planning meeting was held with the appropriate DEP regional office staff to discuss effluent limitations necessary to meet the requirements of the interstate or international compact.

**4. Tributaries To The Chesapeake Bay**

- The proposed project result in a new or increased discharge of sewage into a tributary to the Chesapeake Bay. This proposal for a new sewage treatment facility or new flows to an existing facility includes total nitrogen and total phosphorus in the following amounts: \_\_\_\_\_ pounds of TN per year, and \_\_\_\_\_ pounds of TP per year. Based on the process design and effluent limits, the total nitrogen treatment capacity of the wastewater treatment facility is \_\_\_\_\_ pounds per year and the total phosphorus capacity is \_\_\_\_\_ pounds per year as determined by the wastewater treatment facility permittee. The permittee has determined that the additional TN and TP to be contributed by this project (as modified by credits and/or offsets to be provided) will not cause the discharge to exceed the annual total mass limits for these parameters. Documentation of compliance with nutrient allocations is attached.

Name of Permittee Agency, Authority, Municipality \_\_\_\_\_

Initials of Responsible Agent (See Section G 2.b) \_\_\_\_\_

See *Special Instructions* (Form 3800-FM-BPNPSM0353-1) for additional information on Chesapeake Bay watershed requirements.

**J. CHAPTER 94 CONSISTENCY DETERMINATION** (See Section J of instructions)

Projects that propose the use of existing municipal collection, conveyance or wastewater treatment facilities, or the construction of collection and conveyance facilities to be served by existing municipal wastewater treatment facilities must be consistent with the requirements of Title 25, Chapter 94 (relating to Municipal Wasteload Management). If not previously included in Section F, include a general map showing the path of the sewage to the treatment facility. If more than one municipality or authority will be affected by the project, please obtain the information required in this section for each. Additional sheets may be attached for this purpose.

1. Project Flows 13,238 gpd
2. Total Sewage Flows to Facilities (pathway from point of origin through treatment plant)

When providing "treatment facilities" sewage flows, use Annual Average Daily Flow for "average" and Maximum Monthly Average Daily Flow for "peak" in all cases. For "peak flows" in "collection" and "conveyance" facilities, indicate whether these flows are "peak hourly flow" or "peak instantaneous flow" and how this figure was derived (i.e., metered, measured, estimated, etc.).

- a. Enter average and peak sewage flows for each proposed or existing facility as designed or permitted.
- b. Enter the average and peak sewage flows for the most restrictive sections of the existing sewage facilities.
- c. Enter the average and peak sewage flows, projected for 5 years (2 years for pump stations) through the most restrictive sections of the existing sewage facilities. Include existing, proposed (this project) and future project (other approved projects) flows.

To complete the table, refer to the instructions, Section J.

	a. Design and/or Permitted Capacity (gpd)		b. Present Flows (gpd)		c. Projected Flows in 5 years (gpd) (2 years for P.S.)	
	Average	Peak	Average	Peak	Average	Peak
<b>Collection</b>	6,887,901	24,107,655	3,456	132,392	43,689	152,912
<b>Conveyance</b>	<u>12,100,000</u>	<u>12,100,000</u>	<u>5,100,000</u>	<u>5,810,000</u>	<u>5,180,000</u>	<u>5,895,000</u>
<b>Treatment</b>	<u>250,000,000</u>	<u>250,000,000</u>	<u>199,200,000</u>	<u>250,000,000</u>	<u>248,800,000</u>	<u>295,000,000</u>

3. Collection and Conveyance Facilities

The questions below are to be answered by the sewer authority, municipality, or agency responsible for completing the Chapter 94 report for the collection and conveyance facilities. These questions should be answered in coordination with the latest Chapter 94 annual report and the above table. The individual(s) signing below must be legally authorized to make representation for the organization.

YES NO

- a.  YES  NO This project proposes sewer extensions or tap-ins. Will these actions create a hydraulic overload within five years on any existing collection or conveyance facilities that are part of the system?

If yes, this sewage facilities planning module will not be accepted for review by the municipality, delegated local agency and/or DEP until all inconsistencies with Chapter 94 are resolved or unless there is an approved Corrective Action Plan (CAP) granting an allocation for this project. A letter granting allocations to this project under the CAP must be attached to the module package.

If no, a representative of the sewer authority, municipality, or agency responsible for completing the Chapter 94 report for the collection and conveyance facilities must sign below to indicate that the collection and conveyance facilities have adequate capacity and are able to provide service to the proposed development in accordance with both §71.53(d)(3) and Chapter 94 requirements and that this proposal will not affect that status.

b. Collection System

Name of Agency, Authority, Municipality Pittsburgh Water and Sewer Authority

Name of Responsible Agent Zach Rinker

Agent Signature Zach Rinker Zach Rinker Date 1/10/2024  
2024-01-10

08:29:59 -05'00'

**J. CHAPTER 94 CONSISTENCY DETERMINATION** (See Section J of instructions)

c. Conveyance System

Name of Agency, Authority, Municipality Allegheny County Sanitary Authority (ALCOSAN)

Name of Responsible Agent Joe Fedor

Agent Signature Joe Fedor

Date 1-12-24

4. Treatment Facility

The questions below are to be answered by a representative of the facility permittee in coordination with the information in the table and the latest Chapter 94 report. The individual signing below must be legally authorized to make representation for the organization.

YES NO

- a.   This project proposes the use of an existing wastewater treatment plant for the disposal of sewage. Will this action create a hydraulic or organic overload within 5 years at that facility?

If yes, this planning module for sewage facilities will not be reviewed by the municipality, delegated local agency and/or DEP until this inconsistency with Chapter 94 is resolved or unless there is an approved CAP granting an allocation for this project. A letter granting allocations to this project under the CAP must be attached to the planning module.

If no, the treatment facility permittee must sign below to indicate that this facility has adequate treatment capacity and is able to provide wastewater treatment services for the proposed development in accordance with both §71.53(d)(3) and Chapter 94 requirements and that this proposal will not impact that status.

- b. Name of Agency, Authority, Municipality Allegheny County Sanitary Authority (ALCOSAN)

Name of Responsible Agent Joe Fedor

Agent Signature Joe Fedor

Date 1-12-24

**K. TREATMENT AND DISPOSAL OPTIONS** (See Section K of instructions)

This section is for land development projects that propose construction of wastewater treatment facilities. Please note that, since these projects require permits issued by DEP, these projects may NOT receive final planning approval from a delegated local agency. Delegated local agencies must send these projects to DEP for final planning approval.

Check the appropriate box indicating the selected treatment and disposal option.

- 1. Spray irrigation (other than individual residential spray systems (IRSIS)) or other land application is proposed, and the information requested in Section K.1. of the planning module instructions are attached.
- 2. Recycle and reuse is proposed and the information requested in Section K-2 of the planning module instructions is attached.
- 3. A discharge to a dry stream channel is proposed, and the information requested in Section K.3. of the planning module instructions are attached.
- 4. A discharge to a perennial surface water body is proposed, and the information requested in Section K.4. of the planning module instructions are attached.

**L. PERMEABILITY TESTING** (See Section L of instructions)

- The information required in Section L of the instructions is attached.

**M. PRELIMINARY HYDROGEOLOGIC STUDY** (See Section M of instructions)

- The information required in Section M of the instructions is attached.

**N. DETAILED HYDROGEOLOGIC STUDY** (See Section N of instructions)

The detailed hydrogeologic information required in Section N. of the instructions is attached.

**O. SEWAGE MANAGEMENT** (See Section O of instructions)

**(1-3 for completion by the developer(project sponsor), 4-5 for completion by the non-municipal facility agent and 6 for completion by the municipality)**

Yes No

1.   Is connection to, or construction of, a DEP permitted, non-municipal sewage facility or a local agency permitted, community onlot sewage facility proposed.

If Yes, respond to the following questions, attach the supporting analysis, and an evaluation of the options available to assure long-term proper operation and maintenance of the proposed non-municipal facilities. If No, skip the remainder of Section O.

2. Project Flows \_\_\_\_\_ gpd

Yes No

3.   Is the use of nutrient credits or offsets a part of this project?

If yes, attach a letter of intent to purchase the necessary credits and describe the assurance that these credits and offsets will be available for the remaining design life of the non-municipal sewage facility;

**(For completion by non-municipal facility agent)**

4. Collection and Conveyance Facilities

The questions below are to be answered by the organization/individual responsible for the non-municipal collection and conveyance facilities. The individual(s) signing below must be legally authorized to make representation for the organization.

Yes No

- a.   If this project proposes sewer extensions or tap-ins, will these actions create a hydraulic overload on any existing collection or conveyance facilities that are part of the system?

If yes, this sewage facilities planning module will not be accepted for review by the municipality, delegated local agency and/or DEP until this issue is resolved.

If no, a representative of the organization responsible for the collection and conveyance facilities must sign below to indicate that the collection and conveyance facilities have adequate capacity and are able to provide service to the proposed development in accordance with Chapter 71 §71.53(d)(3) and that this proposal will not affect that status.

- b. Collection System

Name of Responsible Organization \_\_\_\_\_

Name of Responsible Agent \_\_\_\_\_

Agent Signature \_\_\_\_\_

Date \_\_\_\_\_

- c. Conveyance System

Name of Responsible Organization \_\_\_\_\_

Name of Responsible Agent \_\_\_\_\_

Agent Signature \_\_\_\_\_

Date \_\_\_\_\_



5. Treatment Facility

The questions below are to be answered by a representative of the facility permittee. The individual signing below must be legally authorized to make representation for the organization.

Yes No

- a.   If this project proposes the use of an existing non-municipal wastewater treatment plant for the disposal of sewage, will this action create a hydraulic or organic overload at that facility?

If yes, this planning module for sewage facilities will not be reviewed by the municipality, delegated local agency and/or DEP until this issue is resolved.

If no, the treatment facility permittee must sign below to indicate that this facility has adequate treatment capacity and is able to provide wastewater treatment services for the proposed development in accordance with §71.53(d)(3) and that this proposal will not impact that status.

- b. Name of Facility \_\_\_\_\_  
Name of Responsible Agent \_\_\_\_\_  
Agent Signature \_\_\_\_\_  
Date \_\_\_\_\_

**(For completion by the municipality)**

6.  The **SELECTED OPTION** necessary to assure long-term proper operation and maintenance of the proposed non-municipal facilities is clearly identified with documentation attached in the planning module package.

**P. PUBLIC NOTIFICATION REQUIREMENT** (See Section P of instructions)

This section must be completed to determine if the applicant will be required to publish facts about the project in a newspaper of general circulation to provide a chance for the general public to comment on proposed new land development projects. This notice may be provided by the applicant or the applicant's agent, the municipality or the local agency by publication in a newspaper of general circulation within the municipality affected. Where an applicant or an applicant's agent provides the required notice for publication, the applicant or applicant's agent shall notify the municipality or local agency and the municipality and local agency will be relieved of the obligation to publish. The required content of the publication notice is found in Section P of the instructions.

To complete this section, each of the following questions must be answered with a "yes" or "no". Newspaper publication is required if any of the following are answered "yes".

**Yes No**

1.   Does the project propose the construction of a sewage treatment facility ?  
2.   Will the project change the flow at an existing sewage treatment facility by more than 50,000 gallons per day?  
3.   Will the project result in a public expenditure for the sewage facilities portion of the project in excess of \$100,000?  
4.   Will the project lead to a major modification of the existing municipal administrative organizations within the municipal government?  
5.   Will the project require the establishment of *new* municipal administrative organizations within the municipal government?  
6.   Will the project result in a subdivision of 50 lots or more? (onlot sewage disposal only)  
7.   Does the project involve a major change in established growth projections?  
8.   Does the project involve a different land use pattern than that established in the municipality's Official Sewage Plan?

**P. PUBLIC NOTIFICATION REQUIREMENT cont'd.** (See Section P of instructions)


- 9.   Does the project involve the use of large volume onlot sewage disposal systems (Flow > 10,000 gpd)?
- 10.   Does the project require resolution of a conflict between the proposed alternative and consistency requirements contained in §71.21(a)(5)(i), (ii), (iii)?
- 11.   Will sewage facilities discharge into high quality or exceptional value waters?
- Attached is a copy of:
  - the public notice,
  - all comments received as a result of the notice,
  - the municipal response to these comments.
- No comments were received. A copy of the public notice is attached.

**Q. FALSE SWEARING STATEMENT** (See Section Q of instructions)

I verify that the statements made in this component are true and correct to the best of my knowledge, information and belief. I understand that false statements in this component are made subject to the penalties of 18 PA C.S.A. §4904 relating to unsworn falsification to authorities.

Nile J. Barton

Name (Print)



Signature

Professional Land Survey

January 8, 2024

Title

Date

2000 Boles Court, Bethel Park, PA 15102

412-855-3048

Address

Telephone Number

**R. REVIEW FEE** (See Section R of instructions)

The Sewage Facilities Act establishes a fee for the DEP planning module review. DEP will calculate the review fee for the project and invoice the project sponsor **OR** the project sponsor may attach a self-calculated fee payment to the planning module prior to submission of the planning package to DEP. (Since the fee and fee collection procedures may vary if a "delegated local agency" is conducting the review, the project sponsor should contact the "delegated local agency" to determine these details.) Check the appropriate box.

- I request DEP calculate the review fee for my project and send me an invoice for the correct amount. I understand DEP's review of my project will not begin until DEP receives the correct review fee from me for the project.
- I have calculated the review fee for my project using the formula found below and the review fee guidance in the instructions. I have attached a check or money order in the amount of \$ \_\_\_\_\_ payable to "Commonwealth of PA, DEP". Include DEP code number on check. I understand DEP will not begin review of my project unless it receives the fee and determines the fee is correct. If the fee is incorrect, DEP will return my check or money order, send me an invoice for the correct amount. I understand DEP review will NOT begin until I have submitted the correct fee.
- I request to be exempt from the DEP planning module review fee because this planning module creates **only** one new lot and is the **only** lot subdivided from a parcel of land as that land existed on December 14, 1995. I realize that subdivision of a second lot from this parcel of land shall disqualify me from this review fee exemption. I am furnishing the following deed reference information in support of my fee exemption.

County Recorder of Deeds for \_\_\_\_\_ County, Pennsylvania

Deed Volume \_\_\_\_\_ Book Number \_\_\_\_\_

Page Number \_\_\_\_\_ Date Recorded \_\_\_\_\_

**R. REVIEW FEE** (continued)

Formula:

1. For a new collection system (with or without a Clean Streams Law Permit), a collection system extension, or individual tap-ins to an existing collection system use this formula.

$$\# \text{_____ Lots (or EDUs)} \times \$50.00 = \$ \text{_____}$$

The fee is based upon:

- The number of lots created or number of EDUs whichever is higher.
  - For community sewer system projects, one EDU is equal to a sewage flow of 400 gallons per day.
2. For a surface or subsurface discharge system, use the appropriate one of these formulae.

- A. A new surface discharge greater than 2000 gpd will use a flat fee:

\$ 1,500 per submittal (non-municipal)  
\$ 500 per submittal (municipal)

- B. An increase in an existing surface discharge will use:

$$\# \text{_____ Lots (or EDUs)} \times \$35.00 = \$ \text{_____}$$

to a maximum of \$ 1,500 per submittal (non-municipal) or \$ 500 per submittal (municipal)

The fee is based upon:

- The number of lots created or number of EDUs whichever is higher.
  - For community sewage system projects one EDU is equal to a sewage flow of 400 gallons per day.
  - For non-single family residential projects, EDUs are calculated using projected population figures
- C. A sub-surface discharge system that requires a permit under The Clean Streams Law will use a flat fee:
- \$ 1,500 per submittal (non-municipal)  
\$ 500 per submittal (municipal)



COMMONWEALTH OF PENNSYLVANIA  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF CLEAN WATER

DEP Code #: \_\_\_\_\_

**SEWAGE FACILITIES PLANNING MODULE  
 COMPONENT 4A - MUNICIPAL PLANNING AGENCY REVIEW**

**Note to Project Sponsor:** To expedite the review of your proposal, one copy of your completed planning module package and one copy of this *Planning Agency Review Component* should be sent to the local municipal planning agency for their comments.

**SECTION A. PROJECT NAME** (See Section A of instructions)

Project Name  
 Sanfofa Square Development

**SECTION B. REVIEW SCHEDULE** (See Section B of instructions)

1. Date plan received by municipal planning agency 1/18/2024
2. Date review completed by agency 2/1/2024

**SECTION C. AGENCY REVIEW** (See Section C of instructions)

Yes	No	
<input type="checkbox"/>	<input checked="" type="checkbox"/>	1. Is there a municipal comprehensive plan adopted under the Municipalities Planning Code (53 P.S. 10101, <i>et seq.</i> )?
<input type="checkbox"/> N/A	<input type="checkbox"/>	2. Is this proposal consistent with the comprehensive plan for land use? If no, describe the inconsistencies _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	3. Is this proposal consistent with the use, development, and protection of water resources? If no, describe the inconsistencies _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	4. Is this proposal consistent with municipal land use planning relative to Prime Agricultural Land Preservation?
<input type="checkbox"/>	<input checked="" type="checkbox"/>	5. Does this project propose encroachments, obstructions, or dams that will affect wetlands? If yes, describe impacts _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	6. Will any known historical or archaeological resources be impacted by this project? If yes, describe impacts _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	7. Will any known endangered or threatened species of plant or animal be impacted by this project? If yes, describe impacts _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	8. Is there a municipal zoning ordinance?
<input type="checkbox"/>	<input checked="" type="checkbox"/>	9. Is this proposal consistent with the ordinance? If no, describe the inconsistencies <u>In review</u>
<input type="checkbox"/>	<input checked="" type="checkbox"/>	10. Does the proposal require a change or variance to an existing comprehensive plan or zoning ordinance?
<input type="checkbox"/>	<input checked="" type="checkbox"/>	11. Have all applicable zoning approvals been obtained?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	12. Is there a municipal subdivision and land development ordinance?

**SECTION C. AGENCY REVIEW (continued)**

Yes	No	
<input type="checkbox"/>	<input checked="" type="checkbox"/>	13. Is this proposal consistent with the ordinance? If no, describe the inconsistencies <u>In review</u>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	14. Is this plan consistent with the municipal Official Sewage Facilities Plan? If no, describe the inconsistencies _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	15. Are there any wastewater disposal needs in the area adjacent to this proposal that should be considered by the municipality? If yes, describe _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	16. Has a waiver of the sewage facilities planning requirements been requested for the residual tract of this subdivision?
<input type="checkbox"/>	<input type="checkbox"/>	If yes, is the proposed waiver consistent with applicable ordinances? If no, describe the inconsistencies _____
17. Name, title and signature of planning agency staff member completing this section: Name: <u>Kyla Prendergast</u> Title: <u>Senior Environmental Planner</u> Signature: <u><i>Kyla Prendergast</i></u> Date: <u>2/1/2024</u> Name of Municipal Planning Agency: <u>Department of City Planning</u> Address <u>100 Ross Street, Suite 202, Pittsburgh, PA 15219</u> Telephone Number: <u>412-255-2676</u>		

**SECTION D. ADDITIONAL COMMENTS (See Section D of instructions)**

This component does not limit municipal planning agencies from making additional comments concerning the relevancy of the proposed plan to other plans or ordinances. If additional comments are needed, attach additional sheets.

The planning agency must complete this component within 60 days.

This component and any additional comments are to be returned to the applicant.

**SEWAGE FACILITIES PLANNING MODULE  
 COMPONENT 4C - COUNTY OR JOINT HEALTH DEPARTMENT REVIEW**

**Note to Project Sponsor:** To expedite the review of your proposal, one copy of your completed planning module package and one copy of this *Planning Agency Review Component* should be sent to the county or joint county health department for their comments.


**SECTION A. PROJECT NAME** (See Section A of instructions)

Project Name  
Sankofa Square Development

**SECTION B. REVIEW SCHEDULE** (See Section B of instructions)

1. Date plan received by county or joint county health department 01/18/2024  
 Agency name Allegheny County Health Department (ACHD)
2. Date review completed by agency 01/25/2024

**SECTION C. AGENCY REVIEW** (See Section C of instructions)

Yes	No	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	1. Is the proposed plan consistent with the municipality's Official Sewage Facilities Plan? If no, what are the inconsistencies? _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	2. Are there any wastewater disposal needs in the area adjacent to this proposal that should be considered by the municipality? If yes, describe _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	3. Is there any known groundwater degradation in the area of this proposal? If yes, describe _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	4. The county or joint county health department recommendation concerning this proposed plan is as follows: <u>ACHD recommends approval. Please see attached letter.</u>
		5. Name, title and signature of person completing this section: Name: <u>Issa Tijani</u> Title: <u>Environmental Health Engineer</u> Signature: <u></u> Date: <u>01/25/2024</u> Name of County Health Department: <u>Allegheny County Health Department</u> Address: <u>3901 Penn Avenue, Building #5, Pittsburgh, PA 15224</u> Telephone Number: <u>412-578-8046</u>

**SECTION D. ADDITIONAL COMMENTS** (See Section D of instructions)

This component does not limit county planning agencies from making additional comments concerning the relevancy of the proposed plan to other plans or ordinances. If additional comments are needed, attach additional sheets.

The county planning agency must complete this component within 60 days.  
 This component and any additional comments are to be returned to the applicant.

COUNTY OF



ALLEGHENY

SARA INNAMORATO  
COUNTY EXECUTIVE

January 25, 2024

Nile Barton, PLS  
NJ Barton LLC  
2000 Boles Court  
Bethel Park, PA, 15102

**RE: SEWAGE FACILITIES PLANNING MODULE; ALLEGHENY COUNTY  
Sankofa Square Development – City of Pittsburgh**

Dear Mr. Barton:

Enclosed is a signed copy of Component 4C, County or Joint County Health Department Review, for the above-referenced development. This Planning Module Component was received on January 18, 2024. The project proposes the following:

**Project Description:** This project proposed to develop a 4-story commercial mixed -use building and associated parking lot.

**Sewage Flow:** 13,238 GPD

**Conveyance:** Sewage from proposed development will be conveyed through 15-inch VCP and collected by PWSA and then, linked to Monongahela Interceptor and ultimately transported to ALCOSAN at Wood Run Road for treatment.

**Sewer's Owner:** PSWA (collection), ALCOSAN (interceptor)

**Sewage Treatment Plant:** ALCOSAN

Please be advised that a permit must be obtained from the Allegheny County Health Department's (ACHD) Plumbing Section prior to commencing any plumbing work for the proposed project. Plumbing work for which an ACHD Plumbing Permit must be obtained includes any plumbing work done on the site and any sewers, which will not be owned and operated by a municipality or a sewer authority.



**ALLEGHENY COUNTY HEALTH DEPARTMENT**

**WATER POLLUTION CONTROL & SOLID WASTE MANAGEMENT**  
3901 PENN AVENUE • BUILDING 5 • PITTSBURGH, PA 15224-1318  
PHONE: 412.578.8040 • FAX: 412.578.8053  
WWW.ALLEGHENYCOUNTY.US/HEALTHDEPARTMENT



In addition, it should be noted that the approval of this sewage facilities planning module does not include approval of pipe size and/or type. Approval for pipe size and/or type must be obtained by filing a specific plumbing plan with the ACHD's Plumbing Section. If you should have any questions relative to ACHD's plumbing requirements, please contact Drew Grese, Plumbing Program Manager at 412-578-8055.

The ACHD has no objection to the approval of this project. If you have any questions, please call me at 412-578-8046.

Sincerely,


A handwritten signature in black ink, appearing to be 'Issa Tijani', with a long horizontal stroke extending to the right.

Issa Tijani  
Environmental Health Engineer II  
Water Pollution Control & Solid Waste Management


Enclosure


cc: Regis Ryan, PA Department of Environmental Protection w/attachment  
Drew Grese, ACHD w/attachment





**Sankofa Square**  
 2100 block of Centre Ave  
 Pittsburgh, PA 15219




 Project Area

Source: USGS The National Map:  
 Data refreshed May, 2020.

**LOCATION PLAN**





**NOTE :**

- UNDERGROUND UTILITY LOCATIONS SHOWN SHOULD BE CONSIDERED APPROXIMATE. EXACT LOCATIONS AND SIZES MUST BE FIELD VERIFIED UTILIZING THE PA ONE CALL SYSTEM PRIOR TO ANY CONSTRUCTION TAKING PLACE. UTILIZE PA ONE CALL SERIAL NO. 20201740663
- THIS PLAN IN NO WAY IMPLIES THAT ALL UNDERGROUND UTILITIES OR SERVICE LINES HAVE BEEN ACCOUNTED FOR.

**UTILITY SERVICE PROVIDERS / CONTACT :**


- PEOPLES GAS COMPANY, LLC / michael.denny@peoples-gas.com
- CRDWN CASTLE / tyler.stein@crowncastle.com
- VERIZON PENNSYLVANIA, LLC / deborah.d.delia@verizon.com
- PITTSBURGH WATER & SEWER AUTHORITY / robermeier@pgh2o.com
- PITTSBURGH CITY DEPARTMENT OF MOBILITY & INFRASTRUCTURE / brian.ralston@pittsburghpa.gov
- ALLEGHENY CITY ELECTRIC / tmualleghenyelectric.com
- DUQUESNE LIGHT COMPANY / kparison@duqlight.com
- COMCAST / charles\_detwiler@cable.comcast.com

**PROPERTY REFERENCE :**

- BEING A CONSOLIDATION OF TAX PARCEL BLOCK 10 - P ; LOT NUMBERS 102, 104, 105, 106, 107, & 108

**PROJECT SCOPE :**

- A PROPOSED PRIVATE PARKING LOT WILL BE AN ACCESSORY FOR THIS PROPOSED BUILDING TO BE USED AS RESTAURANT AND OFFICE SPACE. THE LOT WILL NOT BE FOR COMMERCIAL PARKING.




**ZONING BOARD OF ADJUSTMENT REQUESTS FOR APPLICATION DCP-ZDR-2021-09681:**

Date of Hearing: July 20, 2023 (virtual)  
 Date of Decision: September 2023 Request approved

- Special Exception - Off-Site Parking (914.07.G.2(a))
- Special Exception - restaurant (general) in the LNC District (911.02 and 911.04.A.57)
- Variance - Accessory use (off-street parking) in a different zoning district than the primary use (914.07.G.2(a))
- Variance - 2:1 Floor Area Ratio, proposed 3.5:1 (904.02.C)
- Variance - Maximum permitted height is 45/3 stories, proposed 4 stories (904.02.C)
- Variance - 113 parking stalls required, 78 proposed (914.02.A)
- Variance - 25' front and exterior side required, 22', 15', 8' and 0.50' proposed (903.03.C)
- Variance - 10' interior side setback required, 0' proposed (903.03.C)

CALL BEFORE YOU DIG!  
 PENNSYLVANIA LAW REQUIRES  
 3 WORKING DAYS NOTICE FOR  
 CONSTRUCTION PHASE AND 10 WORKING  
 DAYS IN DESIGN STAGE-STOP CALL  
 Pennsylvania One Call System, Inc.

1-800-242-1776



LOCATION PLAN

**LEGEND :**

- EXISTING MANHOLE - ○ MH
- EXISTING GAS VALVE - ○ GV
- EXISTING WATER VALVE - ○ WV
- EXISTING OVERHEAD ELECTRIC WIRES - — E — E —
- EXISTING UNDERGROUND ELECTRIC WIRES - — DL — DL —
- APPROXIMATE UNDERGROUND GAS LINE - — G — G —
- APPROXIMATE UNDERGROUND WATER LINE - — W — W —
- APPROXIMATE UNDERGROUND CABLE LINE - — C — C —
- EXISTING UNDERGROUND COMBINED SEWER - — CS — CS —
- EXISTING UNDERGROUND SANITARY SEWER - — SAN — SAN —
- EXISTING UNDERGROUND STORM SEWER - — ST — ST —
- EXISTING TRAFFIC FLOW DIRECTION - ← →
- EXISTING CONCRETE PAD / SIDEWALK - [Pattern]
- EXISTING SEWER FLOW DIRECTION - → ←
- PROPOSED INTER-LOK WALL W/ RAIL - [Pattern]
- EXISTING ONE FOOT CONTOUR - — 900 —
- EXISTING SPOT ELEVATION - × 900.00
- TEST BORING LOCATION - ○ TB
- PROPOSED 3'x10' STREET TREE BOX - [Symbol]

**ZONING :**

- PARKING LOT: "RM-M" (Multi-Unit Residential Moderate Density)**
- MIN. LOT SIZE: 3,200 sq. ft.
  - MIN. LOT SIZE PER UNIT: 1,800 sq. ft.
  - MIN. FRONT SETBACK: 25'
  - MIN. REAR SETBACK: 25'
  - MIN. EXTERIOR YARD SETBACK: 25'
  - MIN. EXTERIOR SIDE YARD SETBACK: 25'
  - MIN. INTERIOR SIDE YARD SETBACK: 10'
  - MAX. BUILDING HEIGHT: 55' (not exceeding 4 stories)
- BUILDING: "LNC" (Local Neighborhood Commercial District)**
- MIN. LOT SIZE: 0 sq. ft.
  - MAX. FLOOR AREA RATIO: 2:1
  - MAX. LOT COVERAGE: 90%
  - MIN. FRONT SETBACK: 0'
  - MIN. REAR SETBACK: 20'
  - 0' if abuts a way
  - MIN. EXTERIOR SIDE YARD SETBACK: 0'
  - MIN. INTERIOR SIDE YARD SETBACK: 0'
  - MAX. BUILDING HEIGHT: 45' (not exceeding 3 stories)

**\* NOT APPROVED FOR CONSTRUCTION**



*Nile J. Barton*

TOTAL AREA = 16,286.90 SQ.FT. / 0.374 ACRE


**PROPOSED SANKOFA SQUARE  
 " BUILDING SITE PLAN "  
 REFERENCE PARCEL "A"**

SITUATE IN :  
 5th WARD, CITY OF PITTSBURGH  
 ALLEGHENY COUNTY, PA

FDR :  
**SANKOFA GROUP**  
 1801 CENTRE AVENUE, SUITE 305, PITTSBURGH, PA 15219

SCALE : 1" = 20'      DATE : SEPTEMBER 20, 2022

**NJBarton, LLC**  
 Professional Land Surveying  
 2000 Boles Court  
 Bethel Park, PA. 15102  
 412.855.3048    njbartonllc@gmail.com



REVISED : OCTOBER 2, 2023  
 REVISED : FEBRUARY 08, 2023



The Sankofa Group  
1801 Centre Avenue, Suite 305  
Pittsburgh, PA 15219

## Project Narrative

### **How does this project provide a benefit or improvement to a community?**

Located on Centre Avenue in the heart of the historic Hill District neighborhood in the City of Pittsburgh, Sankofa Square will be the first multi-tenant Class A office building. Centre Avenue is one of the Urban Redevelopment Authority's Avenues of Hope, an initiative aimed at investing in Black-owned businesses and commercial corridor activation.

As a MWBE mixed use, new construction project on a vacant lot, it will implement the neighborhood's updated Master Plan goal of Economic Empowerment and Commercial Development.

The Hill District is a Healthy Food Priority Area (FeedPGH Report). Smoketown Culinary will occupy the ground floor and bring a new food concept to the Avenue, providing space for restaurant entrepreneurs and helping to address the food apartheid issue. Smoketown will honor the rich history of the community, knitting together art, music and great food and serve as a launching site for entrepreneurs who will grow beyond the hall.

### **What will this project entail?**

Sankofa Square will be a 45,000 SF, 4-story steel structure with glazing, masonry and tile accents on the exterior. Located in the 2100 block of Centre Avenue in the Upper Hill District, this new construction, mixed-use building will be home for the Developer's offices and essential local businesses.

Smoketown Culinary will occupy approximately 12,000 square feet on the ground floor. The Developer envisions an "open air" atmosphere. The space includes a central bar, live entertainment stage, main kitchen, and eight food vendors.

The second and third floors of the office building will provide professional office space for lease, including a small office for The Sankofa Group, owner and developer. The rooftop will feature an outdoor patio venue large enough to host small events holding up to 250 people.

The parking lot will be located adjacent to Hemans Street, providing parking for all building tenants and visitors.

# NJBarton, LLC

---

## Sankofa Square Development Alternative Analysis:

The Sankofa Square Development is proposed as a 45,000 SF, 4-story steel structure located in the 2100 block of Centre Avenue in the Upper Hill District, City of Pittsburgh. This new construction will be a mixed-use building with a first-floor food court and 2<sup>nd</sup> and 3<sup>rd</sup>-floor office space. The rooftop will feature an outdoor patio venue large enough to host small events holding up to 250 people. The parking lot will be located adjacent to Hemans Street, providing parking for all building tenants and visitors.

According to mapping provided by PWSA, there is an existing 8" water line located along Centre Avenue and an existing 6" water line located along Hemans Street. Sewage Plans provided by PWSA show an existing 15" sewer located along Hemans Street.

An alternative to connecting to the existing public sanitary sewer line available would be to provide an on-lot sewage system or utilize an on-lot holding tank. Both of these alternatives would require substantial planning for approval and because of the proposed building size, finding a suitable area on site for the system would be difficult. With public sewage available and the existing connections being functional, it is believed this use of existing tap-ins would provide the most logical solution for sewage disposal at this time.

## 1. PROJECT INFORMATION

Project Name: **Sankofa Square Development**

Date of Review: **9/4/2020 11:31:28 AM**

Project Category: **Development, New commercial/industrial development (store, gas station, factory)**

Project Area: **1.37 acres**

County(s): **Allegheny**

Township/Municipality(s): **PITTSBURGH**

ZIP Code: **15219**

Quadrangle Name(s): **PITTSBURGH EAST**

Watersheds HUC 8: **Lower Monongahela**

Watersheds HUC 12: **Streets Run-Monongahela River**

Decimal Degrees: **40.444705, -79.976788**


Degrees Minutes Seconds: **40° 26' 40.9394" N, 79° 58' 36.4351" W**

## 2. SEARCH RESULTS


Agency	Results	Response
PA Game Commission	No Known Impact	No Further Review Required
PA Department of Conservation and Natural Resources	No Known Impact	No Further Review Required
PA Fish and Boat Commission	No Known Impact	No Further Review Required
U.S. Fish and Wildlife Service	No Known Impact	No Further Review Required

As summarized above, Pennsylvania Natural Diversity Inventory (PNDI) records indicate no known impacts to threatened and endangered species and/or special concern species and resources within the project area. Therefore, based on the information you provided, no further coordination is required with the jurisdictional agencies. This response does not reflect potential agency concerns regarding impacts to other ecological resources, such as wetlands.

# Sankofa Square Development




- Project Boundary
- Buffered Project Boundary




Service Layer Credits: Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community  
Esri, HERE, Garmin, (c) OpenStreetMap contributors, and the GIS user community  
Sources: Esri, HERE, Garmin, Intermap, increment P Corp., GEBCO, USGS, FAO, NPS, NRCAN, GeoBase, IGN, Kadaster NL, Ordnance Survey, Esri Japan, METI, Esri China

## Sankofa Square Development



- Project Boundary
- Buffered Project Boundary

Service Layer Credits: Sources: Esri, HERE, Garmin, Intemap, increment P Corp., GEBCO, USGS, FAO, NPS, NRCAN, GeoBase, IGN, Kadaster NL, Ordnance Survey, Esri Japan, METI, Esri China (Hong Kong), (c) OpenStreetMap contributors, and the GIS User Community



## RESPONSE TO QUESTION(S) ASKED

**Q1:** The proposed project is in the range of the Indiana bat. Describe how the project will affect bat habitat (forests, woodlots and trees) and indicate what measures will be taken in consideration of this. Round acreages up to the nearest acre (e.g., 0.2 acres = 1 acre).

**Your answer is:** No forests, woodlots or trees will be affected by the project.

**Q2:** Is tree removal, tree cutting or forest clearing of 40 acres or more necessary to implement all aspects of this project?

**Your answer is:** No

### 3. AGENCY COMMENTS

Regardless of whether a DEP permit is necessary for this proposed project, any potential impacts to threatened and endangered species and/or special concern species and resources must be resolved with the appropriate jurisdictional agency. In some cases, a permit or authorization from the jurisdictional agency may be needed if adverse impacts to these species and habitats cannot be avoided.

These agency determinations and responses are **valid for two years** (from the date of the review), and are based on the project information that was provided, including the exact project location; the project type, description, and features; and any responses to questions that were generated during this search. If any of the following change: 1) project location, 2) project size or configuration, 3) project type, or 4) responses to the questions that were asked during the online review, the results of this review are not valid, and the review must be searched again via the PNDI Environmental Review Tool and resubmitted to the jurisdictional agencies. The PNDI tool is a primary screening tool, and a desktop review may reveal more or fewer impacts than what is listed on this PNDI receipt. The jurisdictional agencies **strongly advise against** conducting surveys for the species listed on the receipt prior to consultation with the agencies.

#### PA Game Commission

##### RESPONSE:

No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

#### PA Department of Conservation and Natural Resources

##### RESPONSE:

No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

#### PA Fish and Boat Commission

##### RESPONSE:

No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

#### U.S. Fish and Wildlife Service

##### RESPONSE:

No impacts to **federally** listed or proposed species are anticipated. Therefore, no further consultation/coordination under the Endangered Species Act (87 Stat. 884, as amended; 16 U.S.C. 1531 et seq. is required. Because no take of federally listed species is anticipated, none is authorized. This response does not reflect potential Fish and Wildlife Service concerns under the Fish and Wildlife Coordination Act or other authorities.



## 4. DEP INFORMATION

The Pa Department of Environmental Protection (DEP) requires that a signed copy of this receipt, along with any required documentation from jurisdictional agencies concerning resolution of potential impacts, be submitted with applications for permits requiring PNDI review. Two review options are available to permit applicants for handling PNDI coordination in conjunction with DEP's permit review process involving either T&E Species or species of special concern. Under sequential review, the permit applicant performs a PNDI screening and completes all coordination with the appropriate jurisdictional agencies prior to submitting the permit application. The applicant will include with its application, both a PNDI receipt and/or a clearance letter from the jurisdictional agency if the PNDI Receipt shows a Potential Impact to a species or the applicant chooses to obtain letters directly from the jurisdictional agencies. Under concurrent review, DEP, where feasible, will allow technical review of the permit to occur concurrently with the T&E species consultation with the jurisdictional agency. The applicant must still supply a copy of the PNDI Receipt with its permit application. The PNDI Receipt should also be submitted to the appropriate agency according to directions on the PNDI Receipt. The applicant and the jurisdictional agency will work together to resolve the potential impact(s). See the DEP PNDI policy at <https://conservationexplorer.dcnr.pa.gov/content/resources>.



## 5. ADDITIONAL INFORMATION

The PNDI environmental review website is a preliminary screening tool. There are often delays in updating species status classifications. Because the proposed status represents the best available information regarding the conservation status of the species, state jurisdictional agency staff give the proposed statuses at least the same consideration as the current legal status. If surveys or further information reveal that a threatened and endangered and/or special concern species and resources exist in your project area, contact the appropriate jurisdictional agency/agencies immediately to identify and resolve any impacts.

For a list of species known to occur in the county where your project is located, please see the species lists by county found on the PA Natural Heritage Program (PNHP) home page ([www.naturalheritage.state.pa.us](http://www.naturalheritage.state.pa.us)). Also note that the PNDI Environmental Review Tool only contains information about species occurrences that have actually been reported to the PNHP.

## 6. AGENCY CONTACT INFORMATION

### PA Department of Conservation and Natural Resources

Bureau of Forestry, Ecological Services Section  
400 Market Street, PO Box 8552  
Harrisburg, PA 17105-8552  
Email: [RA-HeritageReview@pa.gov](mailto:RA-HeritageReview@pa.gov)

### PA Fish and Boat Commission

Division of Environmental Services  
595 E. Rolling Ridge Dr., Bellefonte, PA 16823  
Email: [RA-FBPACENOTIFY@pa.gov](mailto:RA-FBPACENOTIFY@pa.gov)

### U.S. Fish and Wildlife Service

Pennsylvania Field Office  
Endangered Species Section  
110 Radnor Rd; Suite 101  
State College, PA 16801  
Email: [IR1\\_ESPenn@fws.gov](mailto:IR1_ESPenn@fws.gov)  
NO Faxes Please

### PA Game Commission

Bureau of Wildlife Habitat Management  
Division of Environmental Planning and Habitat Protection  
2001 Elmerton Avenue, Harrisburg, PA 17110-9797  
Email: [RA-PGC\\_PNDI@pa.gov](mailto:RA-PGC_PNDI@pa.gov)  
NO Faxes Please

## 7. PROJECT CONTACT INFORMATION

Name: CHRISTINE BARTON  
Company/Business Name: E. HOLDINGS  
Address: 1801 CENTRE AVENUE, SUITE 313  
City, State, Zip: PITTSBURGH, PA 15219  
Phone: (412) 434-6571 Fax: ( )  
Email: christine.barton@eholdingsinc.com

## 8. CERTIFICATION

I certify that ALL of the project information contained in this receipt (including project location, project size/configuration, project type, answers to questions) is true, accurate and complete. In addition, if the project type, location, size or configuration changes, or if the answers to any questions that were asked during this online review change, I agree to re-do the online environmental review.

Christine E. Barton  
applicant/project proponent signature

9/7/2020  
date



November 7, 2023

*Sent Via PA-SHARE*

RE: ER Project # 2023PR05053.001, Sankofa Square Development, Department of Conservation and Natural Resources, Pittsburgh City, Allegheny County

Dear Submitter,

Thank you for submitting information concerning the above referenced project. The Pennsylvania State Historic Preservation Office (PA SHPO) reviews projects in accordance with state and federal laws. Section 106 of the National Historic Preservation Act of 1966, and the implementing regulations (36 CFR Part 800) of the Advisory Council on Historic Preservation, is the primary federal legislation. The Environmental Rights amendment, Article 1, Section 27 of the Pennsylvania Constitution and the Pennsylvania History Code, 37 Pa. Cons. Stat. Section 500 et seq. (1988) is the primary state legislation. These laws include consideration of the project's potential effects on both historic and archaeological resources.

**Above Ground Resources**

*No Above Ground Concerns - Environmental Review - No Effect - Above Ground*

Based on the information received and available within our files, it is our opinion that the proposed project will have No Effect on above ground historic properties, including historic buildings, districts, structures, and/or objects, should they exist. Should the scope of the project change and/or should you be made aware of historic property concerns, you will need to reinitiate consultation with our office using PA-SHARE.

For questions concerning above ground resources, please contact Taylor Napoleon at [tnapoleon@pa.gov](mailto:tnapoleon@pa.gov).

**Archaeological Resources**

*No Archaeological Concerns - Environmental Review - No Effect - Archaeological*

Based on the information received and available in our files, in our opinion, the proposed project should have No Effect on archaeological resources. Our analysis indicates that archaeological resources are potentially located in this project area. Should the scope of the project be amended to include additional ground-disturbing activity and/or should you be made aware of historic property concerns, you will need to reinitiate consultation with our office using PA-SHARE.

For questions concerning archaeological resources, please contact Kristen Walczesky at [kwalczesky@pa.gov](mailto:kwalczesky@pa.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "Emma Diehl". The signature is fluid and cursive, with a long horizontal stroke at the end.

Emma Diehl

Environmental Review Division Manager



# Follow the Flush!

See where your wastewater goes when you flush!

A project by:



3 Rivers  
Wet Weather



CIVICMAPPER

Improving our region's water quality

