



SEWAGE FACILITIES PLANNING MODULE COMPONENT 3

Grandview Avenue Townhomes – Additional Units

SITUATE IN:

CITY OF PITTSBURGH
ALLEGHENY COUNTY, PENNSYLVANIA

PREPARED FOR:

Laurel Communities
2585 Washington Road
Pittsburgh, PA 15241

202110168

November 13, 2023

TABLE OF CONTENTS

- **Sewage Facilities Planning Module – Component 3**
- **Appendix**
 - Site Location Map
 - Soils Map
 - Supplement to Section E – Water Availability Letter from PWSA
 - Supplement to Section F – Project Narrative
 - Supplement to Section G.3 – Plot Plans for Sewage Facilities Planning Purposes
 - Supplement to Section G.4 – Wetland Protection
 - Supplement to Section G.7 – Threatened Species (PNDI)
 - Supplement to Section H – Alternative Sewage Facilities Analysis
 - Supplement to Section J – Flow Table Footnotes and Dry Weather Flow Calculation
 - Supplement to Section J – Sewage Flow Path Map
 - Component 4A - Municipal Planning Agency Review
 - Component 4C - County or Joint Health Department Review

Code No.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF POINT AND NON-POINT SOURCE MANAGEMENT

SEWAGE FACILITIES PLANNING MODULE

Component 3. Sewage Collection and Treatment Facilities

(Return completed module package to appropriate municipality)

DEP USE ONLY				
DEP CODE #	CLIENT ID #	SITE ID #	APS ID #	AUTH ID #

This planning module component is used to fulfill the planning requirements of Act 537 for the following types of projects: (1) a subdivision to be served by sewage collection, conveyance or treatment facilities, (2) a tap-in to an existing collection system with flows on a lot of 2 EDU's or more, or (3) the construction of, or modification to, wastewater collection, conveyance or treatment facilities that will require DEP to issue or modify a Clean Streams Law permit. Planning for any project that will require DEP to issue or modify a permit cannot be processed by a delegated agency. Delegated agencies must send their projects to DEP for final planning approval.

This component, along with any other documents specified in the cover letter, must be completed and submitted to the municipality with jurisdiction over the project site for review and approval. All required documentation must be attached for the Sewage Facilities Planning Module to be complete. Refer to the instructions for help in completing this component.

REVIEW FEES: Amendments to the Sewage Facilities Act established fees to be paid by the developer for review of planning modules for land development. These fees may vary depending on the approving agency for the project (DEP or delegated local agency). Please see section R and the instructions for more information on these fees.

NOTE: All projects must complete Sections A through I, and Sections O through R. Complete Sections J, K, L, M and/or N if applicable or marked .

A. PROJECT INFORMATION (See Section A of instructions)

1. Project Name Grandview Avenue Townhomes - Additional Units

2. Brief Project Description The project initially received Sewage Facilities Planning approval for 26 townhomes on 11/22/2022. This module includes the addition of one (1) townhome and one (1) additional bedroom to eight (8) of the townhomes included in the previously approved plan.

B. CLIENT (MUNICIPALITY) INFORMATION (See Section B of instructions)

Municipality Name	County	City	Boro	Twp
Pittsburgh	Allegheny	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Municipality Contact Individual - Last Name	First Name	MI	Suffix	Title
Prendergast	Kyla			Senior Environmental Planner

Additional Individual Last Name	First Name	MI	Suffix	Title
---------------------------------	------------	----	--------	-------

Municipality Mailing Address Line 1	Mailing Address Line 2
Department of City Planning	200 Ross Street, Suite 4

Address Last Line -- City	State	ZIP+4
Pittsburgh	PA	15219

Area Code + Phone + Ext.	FAX (optional)	Email (optional)
412-255-8800		kyla.prendergast@pittsburghpa.gov

C. SITE INFORMATION (See Section C of instructions)

Site (Land Development or Project) Name

Grandview Avenue Townhomes - Additional Units

Site Location Line 1

Grandview Avenue, Shaller Street, & Agusta Street

Site Location Line 2

Site Location Last Line -- City

Pittsburgh

State

PA

ZIP+4

15211

Latitude

40.4400

Longitude

-80.0230

Detailed Written Directions to Site Rt. 65 to the West End Bridge, continue onto Rt. 51 westbound, quick turn onto Steuben St, Right onto Wabash St. (becomes Greentree Rd.) Left onto Woodville Ave, Left onto Minnotto Sq, Continue onto Shaler Street. Project Site is located at the terminus of Shaller Street at Grandview Ave.

Description of Site The site currently consists of open lawn space, public sidewalk and a few trees. Six (6) single family homes have been demolished on the project site in the within the past 15 years. This module is for the construction of (1) additional townhome and the possibility of adding an additional bedroom to eight (8) units. The overall proposed site will include 27 new townhomes.

Site Contact (Developer/Owner)

Last Name

Marty

First Name

Gillespie

MI

Suffix

Phone

(412) 770-7029

Ext.

Site Contact Title

Principal

Site Contact Firm (if none, leave blank)

FAX

Email

marty@laurelcommunities.com

Mailing Address Line 1

2543 Washington Road

Mailing Address Line 2

Mailing Address Last Line -- City

Pittsburgh

State

PA

ZIP+4

15241

D. PROJECT CONSULTANT INFORMATION (See Section D of instructions)

Last Name

Brennan

First Name

Dillon

MI

Suffix

Title

Civil Project Engineer

Consulting Firm Name

PVE, LLC

Mailing Address Line 1

2000 GEORGETOWNE DRIVE

Mailing Address Line 2

SUITE 101

Address Last Line -- City

SEWICKLEY

State

PA

ZIP+4

15143

Country

USA

Email

dbrennan@pve-llc.com

Area Code + Phone

724-444-1100

Ext.

542

Area Code + FAX

724-444-1104

E. AVAILABILITY OF DRINKING WATER SUPPLY

The project will be provided with drinking water from the following source: (Check appropriate box)

- Individual wells or cisterns.
- A proposed public water supply.
- An existing public water supply.

If existing public water supply is to be used, provide the name of the water company and attach documentation from the water company stating that it will serve the project.

Name of water company: Pittsburgh Water and Sewer Authority

F. PROJECT NARRATIVE (See Section F of instructions)

- A narrative has been prepared as described in Section F of the instructions and is attached.

The applicant may choose to include additional information beyond that required by Section F of the

instructions.

G. PROPOSED WASTEWATER DISPOSAL FACILITIES (See Section G of instructions)

Check all boxes that apply, and provide information on collection, conveyance and treatment facilities and EDU's served. This information will be used to determine consistency with Chapter 93 (relating to wastewater treatment requirements).

1. COLLECTION SYSTEM

a. Check appropriate box concerning collection system

- New collection system Pump Station Force Main
 Grinder pump(s) Extension to existing collection system Expansion of existing facility

Clean Streams Law Permit Number _____

b. Answer questions below on collection system

Number of EDU's and proposed connections to be served by collection system. EDU's 3.25

Connections 2

Name of:

existing collection or conveyance system Shaler Street - 15" VCP

owner Pittsburgh Water and Sewer Authority

existing interceptor ALLEGHENY/MONONGAHELA/OHIO River Interceptor

owner Allegheny County Sanitary Authority

2. WASTEWATER TREATMENT FACILITY

Check all boxes that apply, and provide information on collection, conveyance and treatment facilities and EDU's served. This information will be used to determine consistency with Chapter(s) 91 (relating to general provisions), 92 (relating to national Pollution Discharge Elimination System permitting, monitoring and compliance) and 93 (relating to water quality standards).

a. Check appropriate box and provide requested information concerning the treatment facility

- New facility Existing facility Upgrade of existing facility Expansion of existing facility

Name of existing facility ALCOSAN Treatment Facility

NPDES Permit Number for existing facility PA 0025984

Clean Streams Law Permit Number _____

Location of discharge point for a new facility. Latitude _____ Longitude _____

b. The following certification statement must be completed and signed by the wastewater treatment facility permittee or their representative.

As an authorized representative of the permittee, I confirm that the AlcoSan
(Name from above) sewage treatment facilities can accept sewage flows from this project without adversely affecting the facility's ability to achieve all applicable technology and water quality based effluent limits (see Section I) and conditions contained in the NPDES permit identified above.

Name of Permittee Agency, Authority, Municipality ALCOsan

Name of Responsible Agent Zach Hughes

Agent Signature [Signature] Date 12/17/2023

(Also see Section I, 4.)

G. PROPOSED WASTEWATER DISPOSAL FACILITIES (Continued)

3. PLOT PLAN

The following information is to be submitted on a plot plan of the proposed subdivision.

- a. Existing and proposed buildings.
- b. Lot lines and lot sizes.
- c. Adjacent lots.
- d. Remainder of tract.
- e. Existing and proposed sewerage facilities. Plot location of discharge point, land application field, spray field, COLDS, or LVCOLDS if a new facility is proposed.
- f. Show tap-in or extension to the point of connection to existing collection system (if applicable).
- g. Existing and proposed water supplies and surface water (wells, springs, ponds, streams, etc.)
- h. Existing and proposed rights-of-way.
- i. Existing and proposed buildings, streets, roadways, access roads, etc.
- j. Any designated recreational or open space area.
- k. Wetlands - from National Wetland Inventory Mapping and USGS Hydric Soils Mapping.
- l. Flood plains or Flood prone areas, floodways, (Federal Flood Insurance Mapping)
- m. Prime Agricultural Land.
- n. Any other facilities (pipelines, power lines, etc.)
- o. Orientation to north.
- p. Locations of all site testing activities (soil profile test pits, slope measurements, permeability test sites, background sampling, etc. (if applicable).
- q. Soils types and boundaries when a land based system is proposed.
- r. Topographic lines with elevations when a land based system is proposed

4. WETLAND PROTECTION

YES NO

- a. Are there wetlands in the project area? If yes, ensure these areas appear on the plot plan as shown in the mapping or through on-site delineation.
- b. Are there any construction activities (encroachments, or obstructions) proposed in, along, or through the wetlands? If yes, Identify any proposed encroachments on wetlands and identify whether a General Permit or a full encroachment permit will be required. If a full permit is required, address time and cost impacts on the project. Note that wetland encroachments should be avoided where feasible. Also note that a feasible alternative **MUST BE SELECTED** to an identified encroachment on an exceptional value wetland as defined in Chapter 105. Identify any project impacts on streams classified as HQ or EV and address impacts of the permitting requirements of said encroachments on the project.

5. PRIME AGRICULTURAL LAND PROTECTION

YES NO

- Will the project involve the disturbance of prime agricultural lands?
If yes, coordinate with local officials to resolve any conflicts with the local prime agricultural land protection program. The project must be consistent with such municipal programs before the sewage facilities planning module package may be submitted to DEP.
If no, prime agricultural land protection is not a factor to this project.
- Have prime agricultural land protection issues been settled?

6. HISTORIC PRESERVATION ACT

YES NO

- Sufficient documentation is attached to confirm that this project is consistent with DEP Technical Guidance 012-0700-001 *Implementation of the PA State History Code* (available online at the DEP website at www.dep.state.pa.us, select "subject" then select "technical guidance"). As a minimum this includes copies of the completed Cultural Resources Notice

(CRN), a return receipt for its submission to the PHMC and the PHMC review letter.

7. PROTECTION OF RARE, ENDANGERED OR THREATENED SPECIES

Check one:

- The "Pennsylvania Natural Diversity Inventory (PNDI) Project Environmental Review Receipt" resulting from my search of the PNDI database and all supporting documentation from jurisdictional agencies (when necessary) is/are attached.
- A completed "Pennsylvania Natural Diversity Inventory (PNDI) Project Planning & Environmental Review Form," (PNDI Form) available at www.naturalheritage.state.pa.us, and all required supporting documentation is attached. I request DEP staff to complete the required PNDI search for my project. I realize that my planning module will be considered incomplete upon submission to the Department and that the DEP review will not begin, and that processing of my planning module will be delayed, until a "PNDI Project Environmental Review Receipt" and all supporting documentation from jurisdictional agencies (when necessary) is/are received by DEP.

Applicant or Consultant Initials _____.

H. ALTERNATIVE SEWAGE FACILITIES ANALYSIS (See Section H of instructions)

- An alternative sewage facilities analysis has been prepared as described in Section H of the attached instructions and is attached to this component.
The applicant may choose to include additional information beyond that required by Section H of the attached instructions.

I. COMPLIANCE WITH WATER QUALITY STANDARDS AND EFFLUENT LIMITATIONS (See Section I of instructions) (Check and complete all that apply.)

1. Waters designated for Special Protection

- The proposed project will result in a new or increased discharge into special protection waters as identified in Title 25, Pennsylvania Code, Chapter 93. The Social or Economic Justification (SEJ) required by Section 93.4c. is attached.

2. Pennsylvania Waters Designated As Impaired

- The proposed project will result in a new or increased discharge of a pollutant into waters that DEP has identified as being impaired by that pollutant. A pre-planning meeting was held with the appropriate DEP regional office staff to discuss water quality based discharge limitations.

3. Interstate and International Waters

- The proposed project will result in a new or increased discharge into interstate or international waters. A pre-planning meeting was held with the appropriate DEP regional office staff to discuss effluent limitations necessary to meet the requirements of the interstate or international compact.

4. Tributaries To The Chesapeake Bay

- The proposed project result in a new or increased discharge of sewage into a tributary to the Chesapeake Bay. This proposal for a new sewage treatment facility or new flows to an existing facility includes total nitrogen and total phosphorus in the following amounts: _____ pounds of TN per year, and _____ pounds of TP per year. Based on the process design and effluent limits, the total nitrogen treatment capacity of the wastewater treatment facility is _____ pounds per year and the total phosphorus capacity is _____ pounds per year as determined by the wastewater treatment facility permittee. The permittee has determined that the additional TN and TP to be contributed by this project (as modified by credits and/or offsets to be provided) will not cause the discharge to exceed the annual total mass limits for these parameters. Documentation of compliance with nutrient allocations is attached.

Name of Permittee Agency, Authority, Municipality _____

Initials of Responsible Agent (See Section G 2.b) _____

See *Special Instructions* (Form 3800-FM-BPNPSM0353-1) for additional information on Chesapeake Bay watershed requirements.

J. CHAPTER 94 CONSISTENCY DETERMINATION (See Section J of instructions)

Projects that propose the use of existing municipal collection, conveyance or wastewater treatment facilities, or the construction of collection and conveyance facilities to be served by existing municipal wastewater treatment facilities must be consistent with the requirements of Title 25, Chapter 94 (relating to Municipal Wasteload Management). If not previously included in Section F, include a general map showing the path of the sewage to the treatment facility. If more than one municipality or authority will be affected by the project, please obtain the information required in this section for each. Additional sheets may be attached for this purpose.

1. Project Flows 1300 gpd
2. Total Sewage Flows to Facilities (pathway from point of origin through treatment plant)

When providing "treatment facilities" sewage flows, use Annual Average Daily Flow for "average" and Maximum Monthly Average Daily Flow for "peak" in all cases. For "peak flows" in "collection" and "conveyance" facilities, indicate whether these flows are "peak hourly flow" or "peak instantaneous flow" and how this figure was derived (i.e., metered, measured, estimated, etc.).

- a. Enter average and peak sewage flows for each proposed or existing facility as designed or permitted.
- b. Enter the average and peak sewage flows for the most restrictive sections of the existing sewage facilities.
- c. Enter the average and peak sewage flows, projected for 5 years (2 years for pump stations) through the most restrictive sections of the existing sewage facilities. Include existing, proposed (this project) and future project (other approved projects) flows.

To complete the table, refer to the instructions, Section J.

	a. Design and/or Permitted Capacity (gpd)		b. Present Flows (gpd)		c. Projected Flows in 5 years (gpd) (2 years for P.S.)	
	Average	Peak	Average	Peak	Average	Peak
Collection	1505764	5270174	38117	152766	46220	161769
Conveyance		2,020,000	335,000	369,000	348,854	383,194
Treatment	250,000,000	250,000,000	194,000,000	250,000,000	248,000,000	295,000,000

3. Collection and Conveyance Facilities

The questions below are to be answered by the sewer authority, municipality, or agency responsible for completing the Chapter 94 report for the collection and conveyance facilities. These questions should be answered in coordination with the latest Chapter 94 annual report and the above table. The individual(s) signing below must be legally authorized to make representation for the organization.

YES NO

- a. YES NO This project proposes sewer extensions or tap-ins. Will these actions create a hydraulic overload within five years on any existing collection or conveyance facilities that are part of the system?

If yes, this sewage facilities planning module will not be accepted for review by the municipality, delegated local agency and/or DEP until all inconsistencies with Chapter 94 are resolved or unless there is an approved Corrective Action Plan (CAP) granting an allocation for this project. A letter granting allocations to this project under the CAP must be attached to the module package.

If no, a representative of the sewer authority, municipality, or agency responsible for completing the Chapter 94 report for the collection and conveyance facilities must sign below to indicate that the collection and conveyance facilities have adequate capacity and are able to provide service to the proposed development in accordance with both §71.53(d)(3) and Chapter 94 requirements and that this proposal will not affect that status.

- b. Collection System

Name of Agency, Authority, Municipality PITTSBURGH WATER AND SEWER AUTHORITY

Name of Responsible Agent Robert Herring

Agent Signature *Robert Herring* Robert Herring Date 11/29/2023

2023.11.29
09:57:01 -05'00'

J. CHAPTER 94 CONSISTENCY DETERMINATION (See Section J of instructions)

c. Conveyance System

Name of Agency, Authority, Municipality Alcosan
Name of Responsible Agent Zach Hughes
Agent Signature [Signature]
Date 12/7/2023

4. Treatment Facility

The questions below are to be answered by a representative of the facility permittee in coordination with the information in the table and the latest Chapter 94 report. The individual signing below must be legally authorized to make representation for the organization.

YES NO

- a. This project proposes the use of an existing wastewater treatment plant for the disposal of sewage. Will this action create a hydraulic or organic overload within 5 years at that facility?

If yes, this planning module for sewage facilities will not be reviewed by the municipality, delegated local agency and/or DEP until this inconsistency with Chapter 94 is resolved or unless there is an approved CAP granting an allocation for this project. A letter granting allocations to this project under the CAP must be attached to the planning module.

If no, the treatment facility permittee must sign below to indicate that this facility has adequate treatment capacity and is able to provide wastewater treatment services for the proposed development in accordance with both §71.53(d)(3) and Chapter 94 requirements and that this proposal will not impact that status.

b. Name of Agency, Authority, Municipality Alcosan
Name of Responsible Agent Zach Hughes
Agent Signature [Signature]
Date 12/7/2023

K. TREATMENT AND DISPOSAL OPTIONS (See Section K of instructions)

This section is for land development projects that propose construction of wastewater treatment facilities. Please note that, since these projects require permits issued by DEP, these projects may NOT receive final planning approval from a delegated local agency. Delegated local agencies must send these projects to DEP for final planning approval.

Check the appropriate box indicating the selected treatment and disposal option.

- 1. Spray irrigation (other than individual residential spray systems (IRSIS)) or other land application is proposed, and the information requested in Section K.1. of the planning module instructions are attached.
- 2. Recycle and reuse is proposed and the information requested in Section K-2 of the planning module instructions is attached.
- 3. A discharge to a dry stream channel is proposed, and the information requested in Section K.3. of the planning module instructions are attached.
- 4. A discharge to a perennial surface water body is proposed, and the information requested in Section K.4. of the planning module instructions are attached.

L. PERMEABILITY TESTING (See Section L of instructions)

- The information required in Section L of the instructions is attached.

M. PRELIMINARY HYDROGEOLOGIC STUDY (See Section M of instructions)

- The information required in Section M of the instructions is attached.

N. DETAILED HYDROGEOLOGIC STUDY (See Section N of instructions)

The detailed hydrogeologic information required in Section N. of the instructions is attached.

O. SEWAGE MANAGEMENT (See Section O of instructions)

(1-3 for completion by the developer(project sponser), 4-5 for completion by the non-municipal facility agent and 6 for completion by the municipality)

Yes No

1. Is connection to, or construction of, a DEP permitted, non-municipal sewage facility or a local agency permitted, community onlot sewage facility proposed.

If Yes, respond to the following questions, attach the supporting analysis, and an evaluation of the options available to assure long-term proper operation and maintenance of the proposed non-municipal facilities. If No, skip the remainder of Section O.

2. Project Flows 1,300 gpd

Yes No

3. Is the use of nutrient credits or offsets a part of this project?

If yes, attach a letter of intent to purchase the necessary credits and describe the assurance that these credits and offsets will be available for the remaining design life of the non-municipal sewage facility;

(For completion by non-municipal facility agent)

4. Collection and Conveyance Facilities

The questions below are to be answered by the organization/individual responsible for the non-municipal collection and conveyance facilities. The individual(s) signing below must be legally authorized to make representation for the organization.

Yes No

- a. If this project proposes sewer extensions or tap-ins, will these actions create a hydraulic overload on any existing collection or conveyance facilities that are part of the system?

If yes, this sewage facilities planning module will not be accepted for review by the municipality, delegated local agency and/or DEP until this issue is resolved.

If no, a representative of the organization responsible for the collection and conveyance facilities must sign below to indicate that the collection and conveyance facilities have adequate capacity and are able to provide service to the proposed development in accordance with Chapter 71 §71.53(d)(3) and that this proposal will not affect that status.

- b. Collection System

Name of Responsible Organization _____

Name of Responsible Agent _____

Agent Signature _____

Date _____

- c. Conveyance System

Name of Responsible Organization _____

Name of Responsible Agent _____

Agent Signature _____

Date _____

5. Treatment Facility

The questions below are to be answered by a representative of the facility permittee. The individual signing below must be legally authorized to make representation for the organization.

Yes No

- a. If this project proposes the use of an existing non-municipal wastewater treatment plant for the disposal of sewage, will this action create a hydraulic or organic overload at that facility?

If yes, this planning module for sewage facilities will not be reviewed by the municipality, delegated local agency and/or DEP until this issue is resolved.

If no, the treatment facility permittee must sign below to indicate that this facility has adequate treatment capacity and is able to provide wastewater treatment services for the proposed development in accordance with §71.53(d)(3) and that this proposal will not impact that status.

- b. Name of Facility _____
Name of Responsible Agent _____
Agent Signature _____
Date _____

(For completion by the municipality)

6. The **SELECTED OPTION** necessary to assure long-term proper operation and maintenance of the proposed non-municipal facilities is clearly identified with documentation attached in the planning module package.

P. PUBLIC NOTIFICATION REQUIREMENT (See Section P of instructions)

This section must be completed to determine if the applicant will be required to publish facts about the project in a newspaper of general circulation to provide a chance for the general public to comment on proposed new land development projects. This notice may be provided by the applicant or the applicant's agent, the municipality or the local agency by publication in a newspaper of general circulation within the municipality affected. Where an applicant or an applicant's agent provides the required notice for publication, the applicant or applicant's agent shall notify the municipality or local agency and the municipality and local agency will be relieved of the obligation to publish. The required content of the publication notice is found in Section P of the instructions.

To complete this section, each of the following questions must be answered with a "yes" or "no". Newspaper publication is required if any of the following are answered "yes".

Yes No

1. Does the project propose the construction of a sewage treatment facility ?
2. Will the project change the flow at an existing sewage treatment facility by more than 50,000 gallons per day?
3. Will the project result in a public expenditure for the sewage facilities portion of the project in excess of \$100,000?
4. Will the project lead to a major modification of the existing municipal administrative organizations within the municipal government?
5. Will the project require the establishment of *new* municipal administrative organizations within the municipal government?
6. Will the project result in a subdivision of 50 lots or more? (onlot sewage disposal only)
7. Does the project involve a major change in established growth projections?
8. Does the project involve a different land use pattern than that established in the municipality's Official Sewage Plan?

P. PUBLIC NOTIFICATION REQUIREMENT cont'd. (See Section P of instructions)

- 9. Does the project involve the use of large volume onlot sewage disposal systems (Flow > 10,000 gpd)?
- 10. Does the project require resolution of a conflict between the proposed alternative and consistency requirements contained in §71.21(a)(5)(i), (ii), (iii)?
- 11. Will sewage facilities discharge into high quality or exceptional value waters?
- Attached is a copy of:
 - the public notice,
 - all comments received as a result of the notice,
 - the municipal response to these comments.
- No comments were received. A copy of the public notice is attached.

Q. FALSE SWEARING STATEMENT (See Section Q of instructions)

I verify that the statements made in this component are true and correct to the best of my knowledge, information and belief. I understand that false statements in this component are made subject to the penalties of 18 PA C.S.A. §4904 relating to unsworn falsification to authorities.

Dillon Brennan, P.E.	<i>Dillon Brennan</i>
Name (Print)	Signature
Civil Project Engineer	11/13/2023
Title	Date
2000 GEORGETOWNE DRIVE, SUITE 101 SEWICKLEY, PA 15143	724-444-1100
Address	Telephone Number

R. REVIEW FEE (See Section R of instructions)

The Sewage Facilities Act establishes a fee for the DEP planning module review. DEP will calculate the review fee for the project and invoice the project sponsor **OR** the project sponsor may attach a self-calculated fee payment to the planning module prior to submission of the planning package to DEP. (Since the fee and fee collection procedures may vary if a "delegated local agency" is conducting the review, the project sponsor should contact the "delegated local agency" to determine these details.) Check the appropriate box.

- I request DEP calculate the review fee for my project and send me an invoice for the correct amount. I understand DEP's review of my project will not begin until DEP receives the correct review fee from me for the project.
- I have calculated the review fee for my project using the formula found below and the review fee guidance in the instructions. I have attached a check or money order in the amount of \$1,300 payable to "Commonwealth of PA, DEP". Include DEP code number on check. I understand DEP will not begin review of my project unless it receives the fee and determines the fee is correct. If the fee is incorrect, DEP will return my check or money order, send me an invoice for the correct amount. I understand DEP review will NOT begin until I have submitted the correct fee.
- I request to be exempt from the DEP planning module review fee because this planning module creates **only** one new lot and is the **only** lot subdivided from a parcel of land as that land existed on December 14, 1995. I realize that subdivision of a second lot from this parcel of land shall disqualify me from this review fee exemption. I am furnishing the following deed reference information in support of my fee exemption.

County Recorder of Deeds for _____ County, Pennsylvania

Deed Volume _____ Book Number _____

Page Number _____ Date Recorded _____

R. REVIEW FEE (continued)

Formula:

1. For a new collection system (with or without a Clean Streams Law Permit), a collection system extension, or individual tap-ins to an existing collection system use this formula.

$$\#3.25 \quad \text{Lots (or EDUs)} \times \$50.00 = \$ 163$$

The fee is based upon:

- The number of lots created or number of EDUs whichever is higher.
 - For community sewer system projects, one EDU is equal to a sewage flow of 400 gallons per day.
2. For a surface or subsurface discharge system, use the appropriate one of these formulae.

- A. A new surface discharge greater than 2000 gpd will use a flat fee:

$$\begin{aligned} & \$ 1,500 \text{ per submittal (non-municipal)} \\ & \$ 500 \text{ per submittal (municipal)} \end{aligned}$$

- B. An increase in an existing surface discharge will use:

$$\# \quad \text{Lots (or EDUs)} \times \$35.00 = \$$$

to a maximum of \$ 1,500 per submittal (non-municipal) or \$ 500 per submittal (municipal)

The fee is based upon:

- The number of lots created or number of EDUs whichever is higher.
 - For community sewage system projects one EDU is equal to a sewage flow of 400 gallons per day.
 - For non-single family residential projects, EDUs are calculated using projected population figures
- C. A sub-surface discharge system that requires a permit under The Clean Streams Law will use a flat fee:
- $$\begin{aligned} & \$ 1,500 \text{ per submittal (non-municipal)} \\ & \$ 500 \text{ per submittal (municipal)} \end{aligned}$$



December 7, 2023

Members of the Board

Sylvia C. Wilson
Chair Person

Shannah Tharp-Gilliam, Ph.D.
Harry Readshaw
Emily Kinkead
Paul Klein
Theresa Kail-Smith
Darrin Kelly

Arletta Scott Williams
Executive Director

Douglas A. Jackson, P.E.
*Director
Operations & Maintenance*

Michelle M. Buys, P.E.
*Director
Environmental Compliance*

Kimberly N. Kennedy, P.E.
*Director
Engineering & Construction*

Karen Fantoni, CPA, CGMA
*Director
Finance*

Michael Lichte, P.E.
*Director
Regional Conveyance*

Jeanne K. Clark
*Director
Governmental Affairs*

Joseph Vallarian
*Director
Communications*

Julie Motley-Williams
*Director
Administration*

Phil Cole
*Chief Information Officer
Information Technology*

Dillon Brennan
PVE, LLC
2000 Georgetowne Drive, Suite 101
Sewickley, PA 15143

**Re: Grandview Avenue Townhomes - Additional Units
City of Pittsburgh – Allegheny County
PA DEP Sewage Facilities Planning Module
ALCOSAN Regulator Structure S-41-00**

Dear Mr. Brennan,

We have reviewed the Component 3 Planning Module for the referenced project to be located at Grandview Ave between Republic Street and Augusta Street in the 19th Ward of the City of Pittsburgh. The project will generate a peak flow of 1300 gpd in the ALCOSAN Saw Mill Run Interceptor and Woods Run Treatment Plant.

The capacity of the ALCOSAN S-41-00 regulator structure is approximately 2.02 MGD. The estimated peak dry weather flow is approximately 0.369 MGD. Therefore, dry weather capacity exists for this connection. However, the Saw Mill Run Interceptor and the Woods Run Treatment Plant do not have the capacity for the flows generated during wet weather periods. This limitation will be addressed as ALCOSAN implements its Clean Water Plan. ALCOSAN requests that this letter be made part of the planning module submission. The signed Component 3 Planning Module is attached. If you have any questions regarding this matter, please contact me at 412-734-6266.

Sincerely,

ALLEGHENY COUNTY SANITARY AUTHORITY

Zach Hughes

Attachment

cc: C. Dean (w/o attachment) R. Herring/PWSA (w/o attachment)
L. Sanford (w/o attachment) Mahuba Iasmin/PADEP (w/o attachment)
M. Lichte (w/o attachment) Issa Tijani /ACHD (w/o attachment)

COUNTY OF



ALLEGHENY

RICH FITZGERALD
COUNTY EXECUTIVE

December 26, 2023

Dillon Brennan, P.E.
PVE, LLC
2000 Georgetown Drive,
Suite 101, Sewickley PA, 15143

**RE: SEWAGE FACILITIES PLANNING MODULE; ALLEGHENY COUNTY
Grandview Avenue Townhomes - Additional Unit – City of Pittsburgh**

Dear Mr. Brennan:

Enclosed is a signed copy of Component 4C, County or Joint County Health Department Review, for the above-referenced development. This Planning Module Component was received on December 14, 2023, and the complete paperwork was received on December 22. The project proposes the following:

Project Description:	This project involves addition of one (1) townhome and one (1) additional bedroom to eight (8) of the townhomes included in the previously approved plan.
Sewage Flow:	1300 GPD
Conveyance:	Sewage from proposed building will be conveyed by PSWA to the Saw Mill Run interceptor and ultimately transported to Woods Run Treatment Plant for treatment.
Sewer's Owner:	PSWA (collection), ALCOSAN (interceptor)
Sewage Treatment Plant:	ALCOSAN

Please be advised that a permit must be obtained from the Allegheny County Health Department's (ACHD) Plumbing Section prior to commencing any plumbing work for the proposed project. Plumbing work for which an ACHD Plumbing Permit must be obtained includes any plumbing work done on the site and any sewers, which will not be owned and operated by a municipality or a sewer authority.



ALLEGHENY COUNTY HEALTH DEPARTMENT
WATER POLLUTION CONTROL & SOLID WASTE MANAGEMENT
3901 PENN AVENUE • BUILDING 5 • PITTSBURGH, PA 15224-1318
PHONE: 412.578.8040 • FAX: 412.578.8053
WWW.ALLEGHENYCOUNTY.US/HEALTHDEPARTMENT



Mr. Dillon Brennan P.E.
December 26, 2023
Page 2

In addition, it should be noted that the approval of this sewage facilities planning module does not include approval of pipe size and/or type. Approval for pipe size and/or type must be obtained by filing a specific plumbing plan with the ACHD's Plumbing Section. If you should have any questions relative to ACHD's plumbing requirements, please contact Drew Grese, Plumbing Program Manager at 412-578-8055.

The ACHD has no objection to the approval of this project. If you have any questions, please call me at 412-578-8046.

Sincerely,




Issa Tijani
Environmental Health Engineer II
Water Pollution Control & Solid Waste Management

Enclosure

cc: Regis Ryan, PA Department of Environmental Protection w/attachment
Drew Grese, ACHD w/attachment

COMPONENT 3
APPENDIX

SITE LOCATION MAP



SITE LOCATION MAP

Grandview Avenue Townhomes

City of Pittsburgh, Allegheny County, Pennsylvania



Waterfront Corporate Park III, Suite 101 P: 724-444-1100
 2000 Georgetown Drive F: 724-444-1104
 Sewickley, PA 15143 www.pve-llc.com

Civil Engineering | Land Development | Planning
 Landscape Architecture | Structures | Environmental



DATE:	06-03-2022
SCALE:	1"=2000'
PROJECT NUMBER:	202110168

Figure 1

SOILS MAP



United States
Department of
Agriculture

NRCS

Natural
Resources
Conservation
Service

A product of the National
Cooperative Soil Survey,
a joint effort of the United
States Department of
Agriculture and other
Federal agencies, State
agencies including the
Agricultural Experiment
Stations, and local
participants

Custom Soil Resource Report for **Allegheny County, Pennsylvania**



Custom Soil Resource Report
Soil Map (202110168 Grandview Avenue Townhomes)



Map Scale: 1:1,240 if printed on A landscape (11" x 8.5") sheet.

0 15 30 60 90 Meters

0 50 100 200 300 Feet

Map projection: Web Mercator Corner coordinates: WGS84 Edge tics: UTM Zone 17N WGS84

MAP LEGEND

Area of Interest (AOI)

 Area of Interest (AOI)

Soils

 Soil Map Unit Polygons

 Soil Map Unit Lines

 Soil Map Unit Points

Special Point Features

-  Blowout
-  Borrow Pit
-  Clay Spot
-  Closed Depression
-  Gravel Pit
-  Gravelly Spot
-  Landfill
-  Lava Flow
-  Marsh or swamp
-  Mine or Quarry
-  Miscellaneous Water
-  Perennial Water
-  Rock Outcrop
-  Saline Spot
-  Sandy Spot
-  Severely Eroded Spot
-  Sinkhole
-  Slide or Slip
-  Sodic Spot

-  Spoil Area
-  Stony Spot
-  Very Stony Spot
-  Wet Spot
-  Other
-  Special Line Features

Water Features

 Streams and Canals

Transportation

-  Rails
-  Interstate Highways
-  US Routes
-  Major Roads
-  Local Roads

Background

 Aerial Photography

MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:15,800.

Warning: Soil Map may not be valid at this scale.

Enlargement of maps beyond the scale of mapping can cause misunderstanding of the detail of mapping and accuracy of soil line placement. The maps do not show the small areas of contrasting soils that could have been shown at a more detailed scale.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service
 Web Soil Survey URL:
 Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: Allegheny County, Pennsylvania
 Survey Area Data: Version 17, Aug 31, 2021

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Sep 25, 2020—Nov 8, 2020

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

Map Unit Legend (202110168 Grandview Avenue Townhomes)

Map Unit Symbol	Map Unit Name	Acres in AOI	Percent of AOI
UGD	Urban land-Guernsey complex, moderately steep	2.2	100.0%
Totals for Area of Interest		2.2	100.0%

Map Unit Descriptions (202110168 Grandview Avenue Townhomes)

The map units delineated on the detailed soil maps in a soil survey represent the soils or miscellaneous areas in the survey area. The map unit descriptions, along with the maps, can be used to determine the composition and properties of a unit.

A map unit delineation on a soil map represents an area dominated by one or more major kinds of soil or miscellaneous areas. A map unit is identified and named according to the taxonomic classification of the dominant soils. Within a taxonomic class there are precisely defined limits for the properties of the soils. On the landscape, however, the soils are natural phenomena, and they have the characteristic variability of all natural phenomena. Thus, the range of some observed properties may extend beyond the limits defined for a taxonomic class. Areas of soils of a single taxonomic class rarely, if ever, can be mapped without including areas of other taxonomic classes. Consequently, every map unit is made up of the soils or miscellaneous areas for which it is named and some minor components that belong to taxonomic classes other than those of the major soils.

Most minor soils have properties similar to those of the dominant soil or soils in the map unit, and thus they do not affect use and management. These are called noncontrasting, or similar, components. They may or may not be mentioned in a particular map unit description. Other minor components, however, have properties and behavioral characteristics divergent enough to affect use or to require different management. These are called contrasting, or dissimilar, components. They generally are in small areas and could not be mapped separately because of the scale used. Some small areas of strongly contrasting soils or miscellaneous areas are identified by a special symbol on the maps. If included in the database for a given area, the contrasting minor components are identified in the map unit descriptions along with some characteristics of each. A few areas of minor components may not have been observed, and consequently they are not mentioned in the descriptions, especially where the pattern was so complex that it was impractical to make enough observations to identify all the soils and miscellaneous areas on the landscape.

The presence of minor components in a map unit in no way diminishes the usefulness or accuracy of the data. The objective of mapping is not to delineate pure taxonomic classes but rather to separate the landscape into landforms or landform segments that have similar use and management requirements. The

Custom Soil Resource Report

delineation of such segments on the map provides sufficient information for the development of resource plans. If intensive use of small areas is planned, however, onsite investigation is needed to define and locate the soils and miscellaneous areas.

An identifying symbol precedes the map unit name in the map unit descriptions. Each description includes general facts about the unit and gives important soil properties and qualities.

Soils that have profiles that are almost alike make up a *soil series*. Except for differences in texture of the surface layer, all the soils of a series have major horizons that are similar in composition, thickness, and arrangement.

Soils of one series can differ in texture of the surface layer, slope, stoniness, salinity, degree of erosion, and other characteristics that affect their use. On the basis of such differences, a soil series is divided into *soil phases*. Most of the areas shown on the detailed soil maps are phases of soil series. The name of a soil phase commonly indicates a feature that affects use or management. For example, Alpha silt loam, 0 to 2 percent slopes, is a phase of the Alpha series.

Some map units are made up of two or more major soils or miscellaneous areas. These map units are complexes, associations, or undifferentiated groups.

A *complex* consists of two or more soils or miscellaneous areas in such an intricate pattern or in such small areas that they cannot be shown separately on the maps. The pattern and proportion of the soils or miscellaneous areas are somewhat similar in all areas. Alpha-Beta complex, 0 to 6 percent slopes, is an example.

An *association* is made up of two or more geographically associated soils or miscellaneous areas that are shown as one unit on the maps. Because of present or anticipated uses of the map units in the survey area, it was not considered practical or necessary to map the soils or miscellaneous areas separately. The pattern and relative proportion of the soils or miscellaneous areas are somewhat similar. Alpha-Beta association, 0 to 2 percent slopes, is an example.

An *undifferentiated group* is made up of two or more soils or miscellaneous areas that could be mapped individually but are mapped as one unit because similar interpretations can be made for use and management. The pattern and proportion of the soils or miscellaneous areas in a mapped area are not uniform. An area can be made up of only one of the major soils or miscellaneous areas, or it can be made up of all of them. Alpha and Beta soils, 0 to 2 percent slopes, is an example.

Some surveys include *miscellaneous areas*. Such areas have little or no soil material and support little or no vegetation. Rock outcrop is an example.

Allegheny County, Pennsylvania

UGD—Urban land-Guernsey complex, moderately steep

Map Unit Setting

National map unit symbol: 15q2
Elevation: 800 to 1,200 feet
Mean annual precipitation: 36 to 46 inches
Mean annual air temperature: 41 to 62 degrees F
Frost-free period: 130 to 170 days
Farmland classification: Not prime farmland

Map Unit Composition

Urban land: 75 percent
Guernsey and similar soils: 15 percent
Minor components: 10 percent
Estimates are based on observations, descriptions, and transects of the mapunit.

Description of Urban Land

Setting

Parent material: Human transported material

Typical profile

H1 - 0 to 6 inches: variable

Properties and qualities

Slope: 8 to 25 percent
Depth to restrictive feature: 10 inches to
Runoff class: Very high

Interpretive groups

Land capability classification (irrigated): None specified
Land capability classification (nonirrigated): 8s
Hydric soil rating: No

Description of Guernsey

Setting

Landform: Hillslopes
Landform position (two-dimensional): Summit, backslope
Landform position (three-dimensional): Side slope
Down-slope shape: Concave, linear
Across-slope shape: Concave
Parent material: Residuum weathered from limestone and calcareous shale

Typical profile

Ap - 0 to 7 inches: silt loam
Bt - 7 to 27 inches: silty clay loam
Btg - 27 to 47 inches: clay
Cg - 47 to 56 inches: silty clay
R - 56 to 63 inches: bedrock

Properties and qualities

Slope: 8 to 15 percent
Depth to restrictive feature: 50 to 75 inches to lithic bedrock
Drainage class: Moderately well drained

Custom Soil Resource Report

Runoff class: Medium

Capacity of the most limiting layer to transmit water (Ksat): Very low to moderately high (0.00 to 0.20 in/hr)

Depth to water table: About 17 to 25 inches

Frequency of flooding: None

Frequency of ponding: None

Available water supply, 0 to 60 inches: Moderate (about 8.4 inches)

Interpretive groups

Land capability classification (irrigated): None specified

Land capability classification (nonirrigated): 3e

Hydrologic Soil Group: C/D

Hydric soil rating: No

Minor Components

Library

Percent of map unit: 5 percent

Hydric soil rating: No

Culleoka

Percent of map unit: 5 percent

Hydric soil rating: No

**WATER AVAILABILITY LETTER
FROM PITTSBURGH WATER AND SEWER
AUTHORITY (PWSA)**

December 22, 2021

Greg Gorman
2000 Georgetown Drive, Suite 101
Sewickley, PA 15143

RE: Water and Sewer Availability
Grandview Avenue & Shaler Street

Dear Mr. Gorman:

In response to your inquiry on 12/21/2021 concerning water and sewer availability for the area referenced above, please be advised that both water and sewers are available near the site, and water and sewer service will be provided in accordance with the policies and procedures of the Pittsburgh Water and Sewer Authority.

We wish to advise you that, if it is your desire to tap our water and sewer mains for service, your plans and Water and Sewer Use Application must be approved by the Authority, complete with detail showing the type of connection, meter, and backflow device before any work is performed.

Please note that the Authority in no way guarantees that the available lines have the capacity or pressure adequate for your project's needs. It is the responsibility of the project developer, design consultant, and/or architects to determine, at their expense, the adequacy of the existing water system to fulfill their needs.

If you plan to make modifications to the water or sewer system, please submit design drawings to The Pittsburgh Water and Sewer Authority for approval.

Refer to the Pittsburgh Water and Sewer Authority (PWSA) website (www.pgh2o.com) for the complete "Procedure Manual for Developers". All tap in plans and applications must be submitted according to the manual.

If you have any questions, please feel free to contact me at (412) 255-8800 x 8030. Thank you.


Sincerely,



Wendy M. Dean
Engineering Tech II

cc: PWSA File

Grandview Ave & Shaler St. - Water



Legend

WATER		SEWER	
Meter	Pressure Monitoring Station	Manhole	Junction
Curb Box	Water Manhole	Inlet	Green Infrastructure Underground Facilities
Water System Pump	Rising Main	Private Inlet	
Hydrant	Supply Main	Outfall	
System Valve	Transmission Main	End Cap	
Dividing Pressure Valve	Distribution Main	Sewer Pump Station	
Coupling	Hydrant Branch	Combined Sewer	
Tee	Private Main	Sanitary Sewer	
Cross	Water Service Line	Storm Sewer	
Reducer		Regulated Combined Sewer	
End Cap		Overflow Sewer	
Wash Out		Interceptor	
		Sewer Force Main	
		Private Sewer	
		Undefined Sewer	


Neither the City of Pittsburgh nor the PWSA guarantees the accuracy of any of the information hereby made available, including but not limited to information concerning the location and condition of underground structures, and neither assumes any responsibility for any conclusions or interpretations made on the basis of such information. COP and PWSA assume no responsibility for any understanding or representations made by their agents or employees unless such understanding or representations are expressly set forth in a duly authorized written document, and such document expressly provides that responsibility therefore is assumed by the City or the PWSA.

Grandview Ave & Shaler St. - Sewer



Legend

- | | | |
|-------------------------|-----------------------------|---|
| WATER | Pressure Monitoring Station | Private Inlet |
| Meter | Water Manhole | Outfall |
| Curb Box | Rising Main | End Cap |
| Water System Pump | Supply Main | Sewer Pump Station |
| Hydrant | Transmission Main | Combined Sewer |
| System Valve | Distribution Main | Sanitary Sewer |
| Dividing Pressure Valve | Hydrant Branch | Storm Sewer |
| Coupling | Private Main | Regulated Combined Sewer |
| Tee | Water Service Line | Overflow Sewer |
| Cross | SEWER | Interceptor |
| Reducer | Manhole | Sewer Force Main |
| End Cap | Junction | Private Sewer |
| Wash Out | Inlet | Undefined Sewer |
| | | Green Infrastructure Underground Facilities |



Neither the City of Pittsburgh nor the PWSA guarantees the accuracy of any of the information hereby made available, including but not limited to information concerning the location and condition of underground structures, and neither assumes any responsibility for any conclusions or interpretations made on the basis of such information. COP and PWSA assume no responsibility for any understanding or representations made by their agents or employees unless such understanding or representations are expressly set forth in a duly authorized written document, and such document expressly provides that responsibility therefore is assumed by the City or the PWSA.

Date: 12/22/2021

SECTION F
PROJECT NARRATIVE

Section F – Project Narrative

Grandview Avenue Townhomes – Additional Units

Proposed Method of Sewage Service:

The Grandview Avenue Townhomes project will include twenty-seven (27) new townhomes units in the Mt. Washington Neighborhood of the City of Pittsburgh. This module accounts for one (1) additional townhome and eight (8) additional bedrooms that will be added to the previously approved 26 townhomes. Twenty-one (21) units will be located along Grandview Avenue beginning at the intersection of Agusta Street and continuing beyond the intersection of Shaller Street, two (2) units are proposed on Agusta Street, and four (4) on Shaller Street (see Figure 1). The project is owned by Laurel Communities and will include the consolidation and subsequent subdivision or lot line revisions of twenty-three (23) existing parcels to establish twenty-six (27) proposed parcels.

Six (6) single family dwellings have been demolished on parcels included in the project since 2010 and are accounted for in historical flows as per PWSA's standards (15 years). The project proposes (27) single family attached townhomes on the 27 lots. Eighteen (18) townhomes will have 3 bedrooms and 2.5 bathrooms, and (9) townhomes will have 4 bedrooms and 2.5 bathrooms.

The equivalent domestic unit of 1 EDU = 400 gallons per day will be used for flow calculations. The proposed additions to the development plan will generate 1,300 gallons per day (GPD). The proposed development will be served by an existing 15" combined sewer line located within Shaler Street according to PWSA records.

Flow monitoring was conducted to determine the flow depth at the most limited capacity sewer. A flow meter was installed in manhole MH006G022 located in Shaler Street. Data was collected for a period of 32 days from June 9th to July 10th, 2022. Flow data during this time period was obtained and tabulated to be used in the calculation section of this module.

Justification of Anticipated Flows:

Proposed Domestic Water and Sanitary Flows

1 single family townhome = 400 GPD

Add 100 GPD for each bedroom over 3 = 100 GPD

(1) 4-bedroom single-family townhome = 400 GPD + 100 GPD = 500 GPD

(1) additional bedroom being added to eight (8) 3-Bedroom townhomes = 8 * 100 GPD = 800 GPD

Total = 500 GPD + 800 GPD = 1,300 GPD or 3.25 EDUs

Previously Approved Flows = 10,400 GPD

Development Total = 10,400 GPD + 1,300 GPD = 11,700 GPD

WETLAND PROTECTION

Section 3.G – Wetland Protection

GRANDVIEW AVENUE TOWNHOMES – ADDITIONAL UNITS

No wetlands are known to exist in the area to be developed for this project

THREATENED SPECIES (PNDI)

1. PROJECT INFORMATION

Project Name: **Grandview Ave. Townhomes**

Date of Review: **1/3/2022 02:39:51 PM**

Project Category: **Development, Residential, Subdivision containing more than 2 lots and/or 2 single-family units**

Project Area: **2.16 acres**

County(s): **Allegheny**

Township/Municipality(s): **PITTSBURGH**

ZIP Code:

Quadrangle Name(s): **PITTSBURGH WEST**

Watersheds HUC 8: **Upper Ohio**

Watersheds HUC 12: **Sawmill Run**

Decimal Degrees: **40.440043, -80.023077**

Degrees Minutes Seconds: **40° 26' 24.1545" N, 80° 1' 23.773" W**

2. SEARCH RESULTS


Agency	Results	Response
PA Game Commission	No Known Impact	No Further Review Required
PA Department of Conservation and Natural Resources	No Known Impact	No Further Review Required
PA Fish and Boat Commission	No Known Impact	No Further Review Required
U.S. Fish and Wildlife Service	No Known Impact	No Further Review Required

As summarized above, Pennsylvania Natural Diversity Inventory (PNDI) records indicate no known impacts to threatened and endangered species and/or special concern species and resources within the project area. Therefore, based on the information you provided, no further coordination is required with the jurisdictional agencies. This response does not reflect potential agency concerns regarding impacts to other ecological resources, such as wetlands.

Grandview Ave. Townhomes



- Project Boundary
- Buffered Project Boundary




Service Layer Credits: Source: Esri, Maxar, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AeroGRID, IGN, and the GIS User Community
Esri, HERE, Garmin, (c) OpenStreetMap contributors, and the GIS user community
Sources: Esri, HERE, Garmin, Intermap, increment P Corp., GEBCO, USGS, FAO, NPS, NRCAN, GeoBase, IGN, Kadaster NL, Ordnance Survey, Esri Japan, METI, Esri China

Grandview Ave. Townhomes



- Project Boundary
- Buffered Project Boundary

Service Layer Credits: Sources: Esri, HERE, Garmin, Intemap, increment P Corp., GEBCO, USGS, FAO, NPS, NRCAN, GeoBase, IGN, Kadaster NL, Ordnance Survey, Esri Japan, METI, Esri China (Hong Kong), (c) OpenStreetMap contributors, and the GIS User Community



RESPONSE TO QUESTION(S) ASKED

Q1: The proposed project is in the range of the Indiana bat. Describe how the project will affect bat habitat (forests, woodlots and trees) and indicate what measures will be taken in consideration of this. Round acreages up to the nearest acre (e.g., 0.2 acres = 1 acre).

Your answer is: The project will affect 1 to 39 acres of forests, woodlots and trees.

Q2: Is tree removal, tree cutting or forest clearing of 40 acres or more necessary to implement all aspects of this project?

Your answer is: No

3. AGENCY COMMENTS

Regardless of whether a DEP permit is necessary for this proposed project, any potential impacts to threatened and endangered species and/or special concern species and resources must be resolved with the appropriate jurisdictional agency. In some cases, a permit or authorization from the jurisdictional agency may be needed if adverse impacts to these species and habitats cannot be avoided.

These agency determinations and responses are **valid for two years** (from the date of the review), and are based on the project information that was provided, including the exact project location; the project type, description, and features; and any responses to questions that were generated during this search. If any of the following change: 1) project location, 2) project size or configuration, 3) project type, or 4) responses to the questions that were asked during the online review, the results of this review are not valid, and the review must be searched again via the PNDI Environmental Review Tool and resubmitted to the jurisdictional agencies. The PNDI tool is a primary screening tool, and a desktop review may reveal more or fewer impacts than what is listed on this PNDI receipt. The jurisdictional agencies **strongly advise against** conducting surveys for the species listed on the receipt prior to consultation with the agencies.

PA Game Commission

RESPONSE:

No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

PA Department of Conservation and Natural Resources

RESPONSE:

No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

PA Fish and Boat Commission

RESPONSE:

No Impact is anticipated to threatened and endangered species and/or special concern species and resources.

U.S. Fish and Wildlife Service

RESPONSE:

No impacts to **federally** listed or proposed species are anticipated. Therefore, no further consultation/coordination under the Endangered Species Act (87 Stat. 884, as amended; 16 U.S.C. 1531 et seq. is required. Because no take of federally listed species is anticipated, none is authorized. This response does not reflect potential Fish and Wildlife Service concerns under the Fish and Wildlife Coordination Act or other authorities.

4. DEP INFORMATION

The Pa Department of Environmental Protection (DEP) requires that a signed copy of this receipt, along with any required documentation from jurisdictional agencies concerning resolution of potential impacts, be submitted with applications for permits requiring PNDI review. Two review options are available to permit applicants for handling PNDI coordination in conjunction with DEP's permit review process involving either T&E Species or species of special concern. Under sequential review, the permit applicant performs a PNDI screening and completes all coordination with the appropriate jurisdictional agencies prior to submitting the permit application. The applicant will include with its application, both a PNDI receipt and/or a clearance letter from the jurisdictional agency if the PNDI Receipt shows a Potential Impact to a species or the applicant chooses to obtain letters directly from the jurisdictional agencies. Under concurrent review, DEP, where feasible, will allow technical review of the permit to occur concurrently with the T&E species consultation with the jurisdictional agency. The applicant must still supply a copy of the PNDI Receipt with its permit application. The PNDI Receipt should also be submitted to the appropriate agency according to directions on the PNDI Receipt. The applicant and the jurisdictional agency will work together to resolve the potential impact(s). See the DEP PNDI policy at <https://conservationexplorer.dcnr.pa.gov/content/resources>.



5. ADDITIONAL INFORMATION

The PNDI environmental review website is a preliminary screening tool. There are often delays in updating species status classifications. Because the proposed status represents the best available information regarding the conservation status of the species, state jurisdictional agency staff give the proposed statuses at least the same consideration as the current legal status. If surveys or further information reveal that a threatened and endangered and/or special concern species and resources exist in your project area, contact the appropriate jurisdictional agency/agencies immediately to identify and resolve any impacts.

For a list of species known to occur in the county where your project is located, please see the species lists by county found on the PA Natural Heritage Program (PNHP) home page (www.naturalheritage.state.pa.us). Also note that the PNDI Environmental Review Tool only contains information about species occurrences that have actually been reported to the PNHP.

6. AGENCY CONTACT INFORMATION

PA Department of Conservation and Natural Resources

Bureau of Forestry, Ecological Services Section
400 Market Street, PO Box 8552
Harrisburg, PA 17105-8552
Email: RA-HeritageReview@pa.gov

PA Fish and Boat Commission

Division of Environmental Services
595 E. Rolling Ridge Dr., Bellefonte, PA 16823
Email: RA-FBPACENOTIFY@pa.gov

U.S. Fish and Wildlife Service

Pennsylvania Field Office
Endangered Species Section
110 Radnor Rd; Suite 101
State College, PA 16801
Email: IR1_ESPenn@fws.gov
NO Faxes Please

PA Game Commission

Bureau of Wildlife Habitat Management
Division of Environmental Planning and Habitat Protection
2001 Elmerton Avenue, Harrisburg, PA 17110-9797
Email: RA-PGC_PNDI@pa.gov
NO Faxes Please

7. PROJECT CONTACT INFORMATION

Name: Dillon Brennan
Company/Business Name: PVE, LLC
Address: 2000 Georgetown Drive, Suite 101
City, State, Zip: Sewickley, PA 15143
Phone: (724) 444-1100 Fax: ()
Email: dbrennan@pve-llc.com

8. CERTIFICATION

I certify that ALL of the project information contained in this receipt (including project location, project size/configuration, project type, answers to questions) is true, accurate and complete. In addition, if the project type, location, size or configuration changes, or if the answers to any questions that were asked during this online review change, I agree to re-do the online environmental review.

Dillon Brennan
applicant/project proponent signature

11-14-2023
date

SECTION H
ALTERNATIVE ANALYSIS

Section H – Alternative Sewage Facilities Analysis

Grandview Avenue Townhomes – Additional Units

Proposed Method of Sewage Disposal

The proposed townhomes will be serviced by a gravity operated collection system owned and operated by Pittsburgh Water and Sewer Authority. The flows will be conveyed into an existing ALCOSAN interceptor and into the ALCOSAN sewage treatment plant.

Alternative Methods Considered

An alternative method of sewage disposal includes an individual septic system. Various factors such as failure rates of septic systems, desirability of developed lot, and size of the developed lot are all deterrents to installing a septic system.


Alternative Alignments Considered

In keeping with the proposed method of sewage disposal, which is to construct a gravity sewer, different alternatives are available with respect to connection point to the existing system. The proposed alignment which will convey sewage from the proposed site to the existing ALCOSAN sewage system was determined to be the optimal layout based on distance, slope, and elevation.

Conclusion

The proposed method of providing sewer service to the proposed townhomes is considered optimum. The fact that an existing sewage interceptor and sewage treatment plant is nearby greatly reduces the justification for thoroughly considering various alternative methods.

SEWAGE FLOW PATH MAP




SEWAGE FLOW PATH MAP

GRANDVIEW AVENUE TOWNHOMES
CITY OF PITTSBURGH, ALLEGHENY COUNTY, PENNSYLVANIA



Waterfront Corporate Park III, Suite 101 P: 724-444-1100
 2000 Georgetown Drive F: 724-444-1104
 Sewickley, PA 15143 www.pve-llc.com

Civil Engineering | Land Development | Planning
 Landscape Architecture | Structures | Environmental



DATE:	06.06.2022
SCALE:	1"=4000'
PROJECT NUMBER:	202110168

FIGURE 3

SECTION J
FLOW TABLE FOOTNOTES AND
DRY WEATHER FLOW CALCULATION

Section J – Chapter 94 Consistency Determination Footnotes

Grandview Avenue Townhomes – Additional Units

- (1) Design/Permitted collection system average design capacity computed using static Manning's analysis based on existing 15" vitrified clay pipe combined sanitary sewer, with slope of 2.11%, Manning's n-value of 0.015 and full flow depth, divided by a peaking factor of 3.5 for combination sewers = **1,505,764 gpd.**
- (2) Design/Permitted collection system peak design capacity computed using static Manning's analysis based on existing 15" vitrified clay pipe combined sanitary sewer, with slope of 2.11%, Manning's n-value of 0.013 and full flow depth = **5,270,174 gpd.**
- (3) Present collection system average flow as determined by analyzing the 30 day sample of flow monitoring data = **38,117 gpd.**
- (4) Present collection system peak flow as determined by analyzing the 30 day sample of flow monitoring data = **152,766 gpd.**
- (5) Projected collection system average flow computed using the present average flows computed in Footnote 3 plus project flows of 1,300 gpd, multiplied by a 5% growth factor = **46,220 gpd.**
- (6) Projected collection system peak flow computed using the present peak flows computed in Footnote 4 plus project flows of 1,300 gpd, see calculations in the project narrative section F of Component 3, multiplied by a 5% growth factor = **161,769 gpd.**

Note: An overview of the Manning's equation calculations reference above are provided on the subsequent page.



Dry Weather Flow and Design Capacity Calculations

Grandview Avenue Townhomes – Additional Units

Given: 15" vitrified clay pipe combined sewer at a slope of 2.11% (S), and Manning's N Value = 0.015.

*Slope taken from MLCS Spreadsheet provided by PWSA

Design Capacity of Pipe Calculation:

Full Flow Capacity, Depth = 15 inches or 1.25 feet (h).

$$\text{Area of Flow in Pipe} = \frac{\pi D^2}{4}, \text{ therefore } A = \frac{\pi(1.25)^2}{4} \quad A = 1.227 \text{ ft}^2$$

$$\text{Wetted Perimeter} = \pi D, \text{ therefore } P = \pi(1.25) = 3.927 \text{ ft}$$

$$\text{Hydraulic Radius } (R_h) = \frac{A}{P}, \text{ therefore } R_h = \frac{1.227}{3.927} = 0.312 \text{ ft}$$

$$Q = \frac{1.49}{n} (R_h)^{\frac{2}{3}} (S)^{\frac{1}{2}} A (0.64632), \text{ therefore}$$

$$Q = \frac{1.49}{0.015} (0.312)^{\frac{2}{3}} (0.0211)^{\frac{1}{2}} (1.227) (0.64632), \quad Q = 5.270 \text{ mgd}$$



**PLOT PLANS FOR
SEWAGE FACILITY PLANNING
PURPOSES**



SFPM PLOT PLAN

Laurel Communities
City of Pittsburgh, Allegheny County, Pennsylvania

This plan has been prepared solely for the benefit of the person(s) named above and for the project noted on this drawing. The use of this plan by any third party, or for any other purpose other than specified, is prohibited without written consent from PVE-LLC.

PLAN REVISIONS	
DATE	DESCRIPTION

P: 724-444-1100
F: 724-444-1104
www.pve-llc.com



Civil Engineering | Land Development | Planning
Landscape Architecture | Structures | Environmental




DATE:	11-13-2023
SCALE:	1"=50'
PROJECT NUMBER:	202110168

FIGURE 2

PROPOSED CONNECTION TO COMBINED SEWER MAIN (UNITS 10-27)

PROPOSED CONNECTION TO COMBINED SEWER MAIN (UNITS 1-9)



COMPONENT 4A
MUNICIPAL PLANNING AGENCY REVIEW



INSTRUCTIONS FOR COMPLETING COMPONENT 4A MUNICIPAL PLANNING AGENCY REVIEW

Remove and recycle these instructions prior to mailing component to the approving agency.

Background

This component, Component 4, is used to obtain the comments of planning agencies and/or health departments having jurisdiction over the project area. It is used in conjunction with other planning module components appropriate to the characteristics of the project proposed.

Who Should Complete the Component?

The component should be completed by any existing municipal planning agency, county planning agency, planning agency with areawide jurisdiction, and/or health department having jurisdiction over the project site. It is divided into sections to allow for convenient use by the appropriate agencies.

The project sponsor must forward copies of this component, along with supporting components and data, to the appropriate planning agency(ies) and health department(s) (if any) having jurisdiction over the development site. These agencies are responsible for responding to the questions in their respective sections of Component 4, as well as providing whatever additional comments they may wish to provide on the project plan. After the agencies have completed their review, the component will be returned to the applicant. The agencies have 60 days in which to provide comments to the applicant. If the agencies fail to comment within this 60 day period, the applicant may proceed to the next stage of the review without the comments. The use of registered mail or certified mail (return receipt requested) by the applicant when forwarding the module package to the agencies will document a date of receipt.

After receipt of the completed Component 4 from the planning agencies, or following expiration of the 60 day period without comments, the applicant must submit the entire component package to the municipality having jurisdiction over the project area for review and action. If approved by the municipality, the proposed plan, along with the municipal action, will be forwarded to the approving agency (Department of Environmental Protection or delegated local agency). The approving agency, in turn, will either approve the proposed plan, return it as incomplete, or disapprove the plan, based upon the information provided.

Instructions for Completing Planning Agency and/or Health Department Review Component

Section A. Project Name

Enter the project name as it appears on the accompanying sewage facilities planning module component (Component 2, 2m, 3, 3s or 3m).

Section B. Review Schedule

Enter the date the package was received by the reviewing agency, and the date that the review was completed.

Section C. Agency Review

1. Answer the yes/no questions and provide any descriptive information necessary on the lines provided. Attach additional sheets, if necessary.
2. Complete the name, title, and signature block.

Section D. Additional Comments

The Agency may provide whatever additional comment(s) it deems necessary, as described in the form. Attach additional sheets, if necessary.



COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER

DEP Code #: _____

**SEWAGE FACILITIES PLANNING MODULE
 COMPONENT 4A - MUNICIPAL PLANNING AGENCY REVIEW**

Note to Project Sponsor: To expedite the review of your proposal, one copy of your completed planning module package and one copy of this *Planning Agency Review Component* should be sent to the local municipal planning agency for their comments.

SECTION A. PROJECT NAME (See Section A of instructions)

Project Name
Grandview Avenue Townhomes - Additional Units

SECTION B. REVIEW SCHEDULE (See Section B of instructions)

1. Date plan received by municipal planning agency 12/14/2023
2. Date review completed by agency 1/4/2024

SECTION C. AGENCY REVIEW (See Section C of instructions)

Yes	No	
<input type="checkbox"/>	<input checked="" type="checkbox"/>	1. Is there a municipal comprehensive plan adopted under the Municipalities Planning Code (53 P.S. 10101, <i>et seq.</i>)?
<input type="checkbox"/>	<input type="checkbox"/>	2. Is this proposal consistent with the comprehensive plan for land use? If no, describe the inconsistencies _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	3. Is this proposal consistent with the use, development, and protection of water resources? If no, describe the inconsistencies _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	4. Is this proposal consistent with municipal land use planning relative to Prime Agricultural Land Preservation?
<input type="checkbox"/>	<input checked="" type="checkbox"/>	5. Does this project propose encroachments, obstructions, or dams that will affect wetlands? If yes, describe impacts _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	6. Will any known historical or archaeological resources be impacted by this project? If yes, describe impacts _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	7. Will any known endangered or threatened species of plant or animal be impacted by this project? If yes, describe impacts _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	8. Is there a municipal zoning ordinance?
<input type="checkbox"/>	<input checked="" type="checkbox"/>	9. Is this proposal consistent with the ordinance? If no, describe the inconsistencies <u>In review</u>
<input type="checkbox"/>	<input checked="" type="checkbox"/>	10. Does the proposal require a change or variance to an existing comprehensive plan or zoning ordinance?
<input type="checkbox"/>	<input checked="" type="checkbox"/>	11. Have all applicable zoning approvals been obtained?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	12. Is there a municipal subdivision and land development ordinance?

SECTION C. AGENCY REVIEW (continued)

- | Yes | No | |
|-------------------------------------|-------------------------------------|--|
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | 13. Is this proposal consistent with the ordinance?
If no, describe the inconsistencies <u>In review</u> |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | 14. Is this plan consistent with the municipal Official Sewage Facilities Plan?
If no, describe the inconsistencies _____ |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | 15. Are there any wastewater disposal needs in the area adjacent to this proposal that should be considered by the municipality?
If yes, describe _____ |
| <input type="checkbox"/> | <input checked="" type="checkbox"/> | 16. Has a waiver of the sewage facilities planning requirements been requested for the residual tract of this subdivision? |
| <input type="checkbox"/> | <input type="checkbox"/> | If yes, is the proposed waiver consistent with applicable ordinances?
If no, describe the inconsistencies
_____ |

17. Name, title and signature of planning agency staff member completing this section:
 Name: Kyla Prendergast
 Title: Senior Environmental Planner
 Signature: *Kyla Prendergast*
 Date: 1/4/2024
 Name of Municipal Planning Agency: City of Pittsburgh Department of City Planning
 Address 100 Ross St, Suite 202, Pittsburgh, PA 15219
 Telephone Number: 412-522-6551

SECTION D. ADDITIONAL COMMENTS (See Section D of instructions)

This component does not limit municipal planning agencies from making additional comments concerning the relevancy of the proposed plan to other plans or ordinances. If additional comments are needed, attach additional sheets.

The planning agency must complete this component within 60 days.

This component and any additional comments are to be returned to the applicant.

COMPONENT 4C
COUNTY HEALTH DEPARTMENT REVIEW



INSTRUCTIONS FOR COMPLETING COMPONENT 4C COUNTY OR JOINT HEALTH DEPARTMENT REVIEW

Remove and recycle these instructions prior to mailing component to the approving agency.

Background

This component, Component 4, is used to obtain the comments of planning agencies and/or health departments having jurisdiction over the project area. It is used in conjunction with other planning module components appropriate to the characteristics of the project proposed.

Who Should Complete the Component?

The component should be completed by any existing municipal planning agency, county planning agency, planning agency with areawide jurisdiction, and/or health department having jurisdiction over the project site. It is divided into sections to allow for convenient use by the appropriate agencies.

The project sponsor must forward copies of this component, along with supporting components and data, to the appropriate planning agency(ies) and health department(s) (if any) having jurisdiction over the development site. These agencies are responsible for responding to the questions in their respective sections of Component 4, as well as providing whatever additional comments they may wish to provide on the project plan. After the agencies have completed their review, the component will be returned to the applicant. The agencies have 60 days in which to provide comments to the applicant. If the agencies fail to comment within this 60 day period, the applicant may proceed to the next stage of the review without the comments. The use of registered mail or certified mail (return receipt requested) by the applicant when forwarding the module package to the agencies will document a date of receipt.

After receipt of the completed Component 4 from the planning agencies, or following expiration of the 60 day period without comments, the applicant must submit the entire component package to the municipality having jurisdiction over the project area for review and action. If approved by the municipality, the proposed plan, along with the municipal action, will be forwarded to the approving agency (Department of Environmental Protection or delegated local agency). The approving agency, in turn, will either approve the proposed plan, return it as incomplete, or disapprove the plan, based upon the information provided.

Instructions for Completing Planning Agency and/or Health Department Review Component

Section A. Project Name

Enter the project name as it appears on the accompanying sewage facilities planning module component (Component 2, 2m, 3, 3s or 3m).

Section B. Review Schedule

Enter the date the package was received by the reviewing agency, and the date that the review was completed.

Section C. Agency Review

1. Answer the yes/no questions and provide any descriptive information necessary on the lines provided. Attach additional sheets, if necessary.
 2. Complete the name, title, and signature block.
-

Section D. Additional Comments

The Agency may provide whatever additional comment(s) it deems necessary, as described in the form. Attach additional sheets, if necessary.

**SEWAGE FACILITIES PLANNING MODULE
 COMPONENT 4C - COUNTY OR JOINT HEALTH DEPARTMENT REVIEW**

Note to Project Sponsor: To expedite the review of your proposal, one copy of your completed planning module package and one copy of this *Planning Agency Review Component* should be sent to the county or joint county health department for their comments.

SECTION A. PROJECT NAME (See Section A of instructions)

Project Name

Grandview Avenue Townhomes - Additional Unit


SECTION B. REVIEW SCHEDULE (See Section B of instructions)

1. Date plan received by county or joint county health department 12/14/2023

Agency name Allegheny County Health Department (ACHD)

2. Date review completed by agency 12/22/2023

SECTION C. AGENCY REVIEW (See Section C of instructions)

Yes	No	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	1. Is the proposed plan consistent with the municipality's Official Sewage Facilities Plan? If no, what are the inconsistencies? _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	2. Are there any wastewater disposal needs in the area adjacent to this proposal that should be considered by the municipality? If yes, describe _____
<input type="checkbox"/>	<input checked="" type="checkbox"/>	3. Is there any known groundwater degradation in the area of this proposal? If yes, describe _____
<input checked="" type="checkbox"/>	<input type="checkbox"/>	4. The county or joint county health department recommendation concerning this proposed plan is as follows: <u>ACHD recommends approval. Please see attached letter.</u>
		5. Name, title and signature of person completing this section: Name: <u>Issa Tijani</u> Title: <u>Environmental Health Engineer</u> Signature:  Date: <u>12/26/2023</u> Name of County Health Department: <u>Allegheny County Health Department</u> Address: <u>3901 Penn Avenue, Building #5, Pittsburgh, PA 15224</u> Telephone Number: <u>412-578-8046</u>

SECTION D. ADDITIONAL COMMENTS (See Section D of instructions)

This component does not limit county planning agencies from making additional comments concerning the relevancy of the proposed plan to other plans or ordinances. If additional comments are needed, attach additional sheets.

The county planning agency must complete this component within 60 days.
 This component and any additional comments are to be returned to the applicant.